

**Blended Fuel Compatibility Form**

Facility - 2042257

**Facility Name** Ogden Minute Man, Inc.  
**Address** 3939 Ogden Avenue  
Chicago, IL 60623  
**County** Cook  
**Contact Name** Nabil Bdour  
**Phone Number** (773) 542-6917

Tank - 5

**Tank Material** Fiberglass Double Wall  
**Tank Capacity** 6,000  
**Tank Product** E-85  
**Tank Install Date** 7/16/2018

**Tank Equipment**

| Compatibility Item     | Model/Manufacturer | Compatibility Method  | Documentation | Comment |
|------------------------|--------------------|-----------------------|---------------|---------|
| Fiberglass Double Wall | XERXES             | Manufacturer Approval |               |         |

**Piping Equipment**

| Compatibility Item   | Model/Manufacturer | Compatibility Method  | Documentation | Comment |
|----------------------|--------------------|-----------------------|---------------|---------|
| Flexible Double Wall | NUPI Smartflex     | Manufacturer Approval |               |         |

**Containment Sump Equipment**

| Compatibility Item                          | Model/Manufacturer                           | Compatibility Method  | Documentation | Comment |
|---------------------------------------------|----------------------------------------------|-----------------------|---------------|---------|
| Single Wall STP/Tanktop Sump/Singlewall UDC | Bravo B407 STP sump/Bravo B1000 S/W UDC sump | Manufacturer Approval |               |         |

**Release Detection Tank Equipment**

| Compatibility Item                                 | Model/Manufacturer | Compatibility Method  | Documentation | Comment |
|----------------------------------------------------|--------------------|-----------------------|---------------|---------|
| Non-Discriminating Interstitial Monitoring Sensors | 794380-345         | Manufacturer Approval |               |         |
| ATG Probe                                          | 846391-107         | Manufacturer Approval |               |         |

**Release Detection Piping Equipment**

| Compatibility Item                                                                    | Model/Manufacturer   | Compatibility Method  | Documentation | Comment |
|---------------------------------------------------------------------------------------|----------------------|-----------------------|---------------|---------|
| Mechanical Pressurized Line Leak Detection                                            | 403169901 STP-MLD+AG | Manufacturer Approval |               |         |
| Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | 794380-323           | Manufacturer Approval |               |         |

**Spill Prevention Equipment**

| Compatibility Item       | Model/Manufacturer | Compatibility Method  | Documentation | Comment |
|--------------------------|--------------------|-----------------------|---------------|---------|
| Single Wall Spill Bucket | OPW 2100 Series    | Manufacturer Approval |               |         |

**Overfill Prevention Equipment**

| Compatibility Item       | Model/Manufacturer | Compatibility Method  | Documentation | Comment |
|--------------------------|--------------------|-----------------------|---------------|---------|
| Overfill Drop Tube Valve | OPW 71SOM          | Manufacturer Approval |               |         |

#### Pump Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method  | Documentation | Comment |
|--------------------|--------------------|-----------------------|---------------|---------|
| STP                | FE Petro STP-AG    | Manufacturer Approval |               |         |
| Dispensers         | Wayne Ovation      | Manufacturer Approval |               |         |

#### Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

#### Joint Dopes & Adhesives Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method  | Documentation | Comment |
|--------------------|--------------------|-----------------------|---------------|---------|
| Pipe Dope          | Gasola E Seal      | Manufacturer Approval |               |         |

#### Correspondence Contact

**Submitter Name** Chris Derro

**Job Title** President

**Company** Cardinal Compliance LLC

**Phone Number** (708) 717-2676

**Email** cderro@cardinalcompliance.net

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.