

**Blended Fuel Compatibility Form**

Facility - 2014287

Facility Name 1600 S Ridgeland Berwyn,
LLC
Address 1600 Ridgeland Ave.
Berwyn, IL 60402
County Cook
Contact Name Syed Fazil
Phone Number (630) 750-1964

Tank - 8

Tank Material Fiberglass Single Wall
Tank Capacity 4,000
Tank Product E85
Tank Install Date 6/25/1999

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall	Containment Solutions	Not Applicable		Tank lining.
Lining Materials Internal	Bridgeport Chemical Glass Armor GA 27P	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall Piping	A.O. Smith	Manufacturer Approval		
Shear Valve	OPW 10	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Franklin	Manufacturer Approval		
Single Wall UDC Sump	Franklin LMM-3617	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	VEEDER-ROOT 846391-407	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Franklin	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	FFS 70547401	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin STPAG33	Manufacturer Approval		
Dispenser	Wayne EB23/5	Manufacturer Approval		
Nozzle	Catlow NEPNL	Manufacturer Approval		
Hose	Goodyear	Manufacturer Approval		

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fill cap	OPW 634TT	Manufacturer Approval		

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Thread sealant	Gasola GE-16	Manufacturer Approval		

Correspondence Contact

Submitter Name Jim Veverka
Job Title Project Manager
Company B&K Equipment Company
Phone Number (708) 474-3344
Email jim.veverka@bkequip.com
Contractor License # IL1207

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.