

**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL****Blended Fuel Compatibility Form**

Facility - 2027155

Facility Name Forest View BP (GEI-164)
Address 4701 S. Central Avenue
 Forest View, IL 60638
County Cook
Contact Name Meghan Fitzpatrick
Phone Number (708) 924-1553

Tank - 9

Tank Material Fiberglass Brine Filled
 Double Wall
Tank Capacity 6,000
Tank Install Date 9/21/2001
Current Product on File Diesel Fuel
Newly Reported Product E-85

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	Existing	Manufacturer Approval	CSI Compatibility...	Existing tank is compatible

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	NUPI Smartflex	Manufacturer Approval	NUPI UL LETTER - ...	
Shear Valve	OPW	Manufacturer Approval	OPW 10 Plus Impac...	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo	Manufacturer Approval	Bravo Sump Compat...	
Single Wall UDC	NUPI	Manufacturer Approval	NUPI UL LETTER - ...	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors	Veeder Root	Manufacturer Approval	Veeder Root Senso...	
ATG Probe	Veeder Root	Manufacturer Approval	Veeder Root E85 p...	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pressurized Line Leak Detection	Veeder Root DPLLD	Manufacturer Approval	Veeder Root Senso...	
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root	Manufacturer Approval	Veeder Root Senso...	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	FE Petro Defender	Manufacturer Approval	FE PETRO DEFENDER...	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	FE Petro Defender	Manufacturer Approval	FFS-0392 Defender...	

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pump Equipment				
Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP	FE Petro STPAPM200	Manufacturer Approval	FE Petro STP Comp...	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasoil E Seal	Manufacturer Approval	Gasoil E-Seal.pd...	

Correspondence Contact

Submitter Name Tim Berg
Job Title President
Company Performance Tank Inc
Phone Number (847) 612-6551
Email tberg@perftank.com
Contractor License # IL881

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.