



### Blended Fuel Compatibility Form

Facility - 2043480

**Facility Name** 89th & Chicago Property, Inc.  
**Address** 8903 S. South Chicago Street  
 Chicago, IL 60617  
**County** Cook  
**Contact Name** Mohamed Mohsin  
**Phone Number** (773) 375-8169

Tank - 4

**Tank Material** Composite Double Wall  
**Tank Capacity** 6,000  
**Tank Install Date** 5/3/2007  
**Current Product on File** Diesel Fuel  
**Newly Reported Product** E85

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glassteel 2	Manufacturer Approval	Glassteel II BioFuels Compatibility 2018.pdf	Existing to remain

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	A.O. Smith Red Thread	Manufacturer Approval	ameron fiberglass pipe.pdf	Existing to remain
Shear Valve	OPW 10 Series	Manufacturer Approval	opw e85 shear valve.pdf	New on permit

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	APT Poly-Tech	Manufacturer Approval	APT Sumps E85 Compatibility Letter 08.07.19.pdf	Existing to remain
Single Wall UDC Sump	Total Containment Enviroflex	Manufacturer Approval	flexpip4 EPA OUST Letter Piping Suppliers.pdf	Existing to remain

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder-Root Model #794380-430	Manufacturer Approval	veeder root sensors all.pdf	New on permit
ATG Probe	Veeder-Root Model #846397-407	Manufacturer Approval	veeder root probes.pdf	New on permit

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder-Root Model #848480-001	Manufacturer Approval	veeder root plld.pdf	Existing to remain
Sump Sensor in Single Wall STP/Tanktop Sump	Veeder-Root Model #794380-323	Manufacturer Approval	veeder root sensors all.pdf	New on permit

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 2100 Series	Manufacturer Approval	Opw spill containers.pdf	Existing to remain

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Defender	Manufacturer Approval	FFS-0392 Defender Series OPV Datasheet.pdf	New on permit

### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	FE Petro STPAG	Manufacturer Approval	franklin stp.pdf	New on permit
Dispenser	Wayne Ovation2 EB23	Manufacturer Approval	Wayne Ovation EB23.pdf	
Nozzle	OPW 11BP	Manufacturer Approval	opw-11bp-series-ethanol-nozzles_2018.pdf	
Hose	Goodyear	Manufacturer Approval	Continental_Goodyear_flex steel hoses.pdf	

### Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fill Cap	OPW	Manufacturer Approval	opw-634-series-tight-fill - top-seal-caps-2018.pdf	

### Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Thread sealant	Gasoil E-Seal	Manufacturer Approval	gasoil dope.pdf	

### Correspondence Contact

**Submitter Name** Ben Olthoff  
**Job Title** Project Manager  
**Company** B&K Equipment  
**Phone Number** (708) 474-3344  
**Email** ben.olthoff@bkequip.com  
**Contractor License #** IL1207

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.