



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 7010002

Facility Name ROC One Stop
Address 309 DeYoung Street
Marion, IL 62959
County Williamson
Contact Name Chelsea Bevely
Phone Number (618) 268-4722

Tank - 7

Tank Material Composite Double Wall
Tank Capacity 5,000
Tank Install Date 10/6/2009
Current Product on File E-85
Newly Reported Product E-15

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel II	Manufacturer Approval	Modern E10-E100.p...	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	APT XP	Lab Certification	FF APT HIGH BLEND...	
Flex Hose	Hose Master FSmm 1.5	Lab Certification	HOSE MASTER FSMM....	
Shear Valve	EBW 662	Lab Certification	EBW 662 SHEAR VAL...	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	APT	Manufacturer Approval	APT SUMPS.pdf	
Single Wall UDC Sump	APT	Manufacturer Approval	APT SUMPS.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Franklin Fueling (Incon) FMP-ULS	Manufacturer Approval	INCON FMP-ULS-MAR...	
ATG Probe	Veeder Root 846396-1XX	Manufacturer Approval	VR Probe-109.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 848480-001	Manufacturer Approval	VR PLLD.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-208	Manufacturer Approval	VR Sump Sensor 20...	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket Insert	Emco	Manufacturer Approval	Emco Stainless In...	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 61SOM	Manufacturer Approval	OPW 61SOM.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submerged Pump	FE Petro STPAG75	Manufacturer Approval	FE Petro STP75AG....	
Dispenser	Wayne Ovation B23 with XFLO upgrade	Manufacturer Approval	Wayne XFLO.pdf	
Hoses	Contitech Futura E25	Manufacturer Approval	Contitech E25.pdf	
Hoses	Contitech Futura Ethan-All	Manufacturer Approval	Contitech E85.pdf	
Breakaway	OPW 66V-0492	Manufacturer Approval	OPW 66V-0492.pdf	
Swivel	OPW 241TPS-0492	Manufacturer Approval	OPW 241TPS-0492.p...	
Nozzles	OPW 21GE	Manufacturer Approval	OPW 21GE.pdf	
Nozzles	OPW 11BP	Manufacturer Approval	OPW 11BP.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Adam Laws

Job Title Sales Rep

Company Mid-South Steel

Phone Number (573) 275-3002

Email adam@midsouthsteel.com

Contractor License # IL1194

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.