



Blended Fuel Compatibility Form

Facility - 2047459

Facility Name	Lenny's Gas N Wash Plano LLC
Address	10000 E. Route 34 Plano, IL 60545
County	Kendall
Contact Name	Leonard McEnery
Phone Number	(708) 444-0117

Tank - 2

Tank Material	Composite Double Wall
Tank Capacity	10,000
Tank Product	E85
Tank Install Date	10/13/2022

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel II	Manufacturer Approval	E85 glass steel 2.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	e85 frp pipe.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single wall UDC	Single wall Bravo	Lab Certification	Bravo Sumps.pdf	
Single Wall STP/Tanktop Sump	Bravo	Manufacturer Approval	e85 bravo.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846397-409	Lab Certification	Magnetostrictive Probes.pdf	
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 794380-430	Lab Certification	Veeder Root Sensors.pdf	From Permit Application

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root plld	Manufacturer Approval	e85 plld.pdf	
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794390-323	Manufacturer Approval	E85 sensors.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	franklin	Manufacturer Approval	e85 franklin spill.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	opw 71SOM	Manufacturer Approval	e85 drop tube.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco Dispensers	gilbarco E700s	Lab Certification	Gilbarco Dispensers.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Caps and Rings	veeder root	Lab Certification	Cap and Ring E85 Compatib ility.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gaseola e seal	Lab Certification	Gasoila Pipe dope.pdf	

Correspondence Contact

Submitter Name Steve Kryl
Job Title Project Manager
Company Anderson Pump Service, Inc.
Phone Number (708) 243-9081
Email steve@andersonpump.com
Contractor License # IL002275

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.