

**Blended Fuel Compatibility Form****Facility - New**

Facility Name Casey's General Stores
#3969
Address 25235 E. Eames Street
Channahon, IL 60410
County Will
Contact Name Lee Lytle
Phone Number (515) 446-6231

Tank - 5

Tank Material Tank - Fiberglass Double Wall
Tank Capacity 8,000
Tank Product E-85
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	CSI Compatibility.pdf	From Permit Application

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech S175SC	Manufacturer Approval	FFS-0524 XP Flexible Pipe work Datasheet.pdf	From Permit Application

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Franklin Tank sump, part #TD4236 and Franklin dispenser sump, part #602375001	Manufacturer Approval	Franklin Fueling Compatibility Products.pdf	From Permit Application

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root, Model #794380-345	Manufacturer Approval	Veeder Root Compatibility .pdf	From Permit Application
ATG Probe	Veeder Root, Model #846391-607	Manufacturer Approval	Veeder Root Compatibility .pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root	Manufacturer Approval	Veeder Root Compatibility .pdf	From Permit Application
Non-Discriminating Sump Sensor with positive shutdown	Veeder Root, Model #794380-323	Manufacturer Approval	Veeder Root Compatibility .pdf	From Permit Application

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Franklin, EBW defender overspill, part #705556111BLK	Manufacturer Approval	Franklin Fueling Compatibility Products.pdf	From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin, part #708691922	Manufacturer Approval	Franklin Defender Series OPV Datasheet.pdf	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
FE Petro Submersible	STPAG75-VL2	Manufacturer Approval	FE Petro Compatibility.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gasket	CSI	Manufacturer Approval	CSI Compatibility.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasola	Manufacturer Approval	Gasola Compatibility.pdf	

Correspondence Contact

Submitter Name Warren Cherner
Job Title President
Company Metro Tank and Pump Company
Phone Number (847) 465-4000
Email info@metrotank.com
Contractor License # IL102

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.