

**Blended Fuel Compatibility Form**

Facility - 7044347

Facility Name Southern F.S. Inc.
Address 1945 Rt. 148
Marion, IL 62959
County Williamson
Contact Name Doug Fox
Phone Number (618) 993-2833

Tank - 3

Tank Material Fiberglass Double Wall
Tank Capacity 15,000
Tank Product B-99
Tank Install Date 7/9/2009

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Aboveground	Steel aboveground pipe	Not Applicable		Aboveground steel pipe

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
NO containment sumps	NO sumps	Not Applicable		No containment sumps

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Franklin Fueling (Incon) FMP-EIS	Manufacturer Approval		
ATG Probe	Franklin Fueling (Incon) TSP-LL2	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Aboveground pipe	No sump sensors, No leak detectors	Not Applicable		Aboveground pipe. No sump sensors, No leak detectors

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	EBW	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Ball Float Vent Valve	EBW 308	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submerged Pump	FE Petro STPAG-5-173-60	Manufacturer Approval		
Meter/Register	Total Control Systems 700-25SPA5AT2	Manufacturer Approval		
Solenoid Valve	Magnatrol F36K47SC-ACVO-SS	Manufacturer Approval		
swing check valve	Morrison Brothers 246ADI	Manufacturer Approval		
opw load arm	OPW Scissor-Type top loading arm	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Daniel Tanner
Job Title Service Manager
Company Southern F.S., Inc.
Phone Number (618) 499-0155
Email dtanner@southernfs.com

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.