

**Blended Fuel Compatibility Form**

Facility - 4047440

Facility Name Love's Travel Stops #867
Address 2007 N. Main Street
Normal, IL 61761
County McLean
Contact Name Kyle Collins
Phone Number (405) 834-0311

Tank - 1

Tank Material Fiberglass Double Wall
Tank Capacity 20,000
Tank Product E-15
Tank Install Date 8/25/2022

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	KBK	Manufacturer Approval	KBK certificate of compliance.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Franklin Fueling Systems UPP	Manufacturer Approval	UPP compatibility.pdf	
Shear Valve	OPW Series 10	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo B487	Manufacturer Approval	Bravo - Sumps Alternative Fuels.pdf	
Single Wall Transition Sump	Bravo B-487	Manufacturer Approval	Bravo - Sumps Alternative Fuels.pdf	
Single Wall UDC Sump	Bravo B1000	Manufacturer Approval	Bravo - Sumps Alternative Fuels.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Franklin FMP EIS	Manufacturer Approval	Franklin Sensors compatibility.pdf	
ATG Probe	Franklin FMP LL3-125-I	Manufacturer Approval	Franklin FMP LL3 125 I inventory probe compatibility.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Franklin LS500	Manufacturer Approval	Franklin ELLD LS500.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Franklin TSP ULS	Manufacturer Approval	Franklin Sensors compatibility.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall Transition Sump	Franklin TSP ULS	Manufacturer Approval	Franklin Sensors compatibility.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Franklin Defender Series	Manufacturer Approval	FFS-0127 Defender Series Spill Containers Datasheet.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Defender Series	Manufacturer Approval	FFS-0392 Defender Series OPV Datasheet.pdf	
Overfill Alarm	Franklin TS RA1	Not Applicable		Overfill alarm doesn't come into contact with fuel.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin STPM200-VL2-XXX	Manufacturer Approval	Loves-E-15 STPM200 8-6-21 .pdf	
Dispenser	Gilbarco 700 Series	Manufacturer Approval	Gilbarco - Encore Dispenser Warranty (under section 6 on page 2).pdf	
Nozzle	OPW 11bp series	Manufacturer Approval	opw-11bp-series-ethanol-nozzles_2018.pdf	
Hose	Continental Futura 559N	Manufacturer Approval	Continental Futura 559N.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dispenser Gaskets	Gilbarco 700 Series dispenser gaskets	Manufacturer Approval	Gilbarco - Encore Dispenser Warranty (under section 6 on page 2).pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dopes	Gasola Eseal E20	Manufacturer Approval	Gasola - E seal E20.pdf	

Correspondence Contact

Submitter Name Ted Lowery
Job Title Manager of Environmental Services
Company Love's Travel Stops and Country Stores
Phone Number (405) 208-3669
Email Ted.Lowery@loves.com

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.