



Blended Fuel Compatibility Form

Facility - 7045691

Facility Name Road Ranger #268
Address 1776 S. Court Street
 Grayville, IL 62844
County Edwards
Contact Name Smantha Hostetler
Phone Number (815) 387-1700

Tank - 3

Tank Material Fiberglass Double Wall
Tank Capacity 20,000
Tank Product B-99
Tank Install Date 9/17/2014

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Ameron Dualoy 3000/ LCX	Manufacturer Approval		
flex connectors	Franklin Fueling/FLEX-ING	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
single wall stp/tanktop sump	Bravo STP Sumps	Manufacturer Approval		
Single Wall STP/Tanktop Sump North	Bravo STP Sumps	Manufacturer Approval		
Single wall UDC	NEF Dispenser Sumps	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Discriminating Interstitial Monitoring Sensors With Monitor	Veeder root 450 / solid state discriminating sensor	Manufacturer Approval		
ATG Probe	Veeder Root 450 TLS Mag Plus Probes	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
European with No Test Req Suction	FE Petro STP MLDS+BD	Manufacturer Approval		
Piping Sump Sensors Not Regulated in Single Wall STP/Tanktop Sump Heater	Veeder Root TLS 450 Solid state non discriminating pan or sump sensor	Manufacturer Approval		
Piping Sump Sensors Not Regulated in Single Wall STP/Tanktop Sump North	Veeder Root/ TLS 450	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1-2100 series	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	Veeder root mag plus stainless steel probe	Manufacturer Approval		
Overfill Drop Tube Valve	OPW71SO-B	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP	FE Petro STPAG	Manufacturer Approval		
Dispensers	Gilbarco Encore S	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Todd Johnston
Job Title project manager
Company Road Ranger L.L.C.
Phone Number (815) 315-2408
Email tjohnston@roadrangerusa.com

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.