

**Blended Fuel Compatibility Form**

Facility - 2011007

Facility Name ISTHA M01 Maintenance
Garage
Address 127th & Cicero on I-294
I-294 MP 12.5
Alsip, IL 60658
County Cook
Contact Name Porto Sam
Phone Number (708) 241-6800

Tank - 11

Tank Material Fiberglass Double Wall
Tank Capacity 10,000
Tank Product E85
Tank Install Date 7/27/2012

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval	Xerxes Tanks.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	Ameron Piping.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Under Dispenser sump	Bravo B-7000-SPLIT-F1M	Manufacturer Approval	Bravo Dispenser Sump.pdf	
Single Wall STP/Tanktop Sump	Xerxes FRP Single wall sump	Manufacturer Approval	Xerxes Sumps.pdf	
Single Wall UDC Sump	Bravo	Manufacturer Approval	Bravo Dispenser Sump.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root probe part number: 846391-410	Manufacturer Approval	Veeder Root Probe & Float .pdf	
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 794380-345	Manufacturer Approval	Veeder Root Sump & Interstitial Sensors.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root	Manufacturer Approval	Veeder Root Compatibility Letter.pdf	
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval	Veeder Root Sump & Interstitial Sensors.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1C-3112P	Manufacturer Approval	OPW Compatibility Matrix. pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill drop tube	Franklin Defender Series 708694902	Manufacturer Approval	FFS-0392 Defender Series OPV Datasheet.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible pump	Red Jacket AGP75S1RJ2	Manufacturer Approval	AG Pump Cut Sheet.pdf	
Dispenser	Wayne E3G/7203D	Manufacturer Approval	Wayne Dispenser Meter.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
dope	Gasolia E-85 compatible	Manufacturer Approval	Gasolia.pdf	

Correspondence Contact

Submitter Name Jason Reed
Job Title Project Manager
Company Stenstrom Petroleum Services Group
Phone Number (630) 878-6354
Email jasonre@rstenstrom.com
Contractor License # IL1890

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.