



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 2005763

Facility Name Citgo
Address 7323 West Randolph Street
Forest Park, IL 60130
County Cook
Contact Name Jay Singh
Phone Number (708) 771-2791

Tank - 6

Tank Material Tank - Composite Double
Wall Modern Welding Glasteel
II
Tank Capacity 4,000
Tank Product E85
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Modern Welding Glasteel II	Manufacturer Approval	Glasteel II Brochure_2.pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Other Pump	Submersible-Franklin Feuling	Manufacturer Approval	FFS-0513+Fuel+Compatibility+Reference+Guide+01-17.pdf	New from Permit Application.
Flex Connector Steel	OPW	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-product-s-2018.pdf	New from Permit Application.
Flexible Double Wall	Franklin Fueling Systems UPP	Manufacturer Approval	FFS-0513+Fuel+Compatibility+Reference+Guide+01-17.pdf	New from Permit Application.
Shear Valves	OPW	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-product-s-2018.pdf	New from Permit Application.

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Petroleum Containment Solutions Inc	Manufacturer Approval	pci-biodiesel.pdf	New from Permit Application.
Not Installed UDC Sump	Bravo Systems	Manufacturer Approval	Bravo+Sump+Compatibility+Statement.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root-794380-430	Manufacturer Approval	577013-750-16_Interstitial_High_Alcohol_Sensor_for_Steel_Tanks.pdf	New from Permit Application.
ATG Probe	Veeder Root -846397-407	Manufacturer Approval	577014-449-08_Stainless_Steel_Mag_Plus_In-Tank_Probe_Alternative_Fluids.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root - 848480-001	Manufacturer Approval	576047-319_Electronic_Pressurized_Line_Leak_Detection_Datasheet.pdf	New from Permit Application.
Sump Sensor with positive shutdown	Veeder Root-794380-423	Manufacturer Approval	577013-750-10_Position_Sensitive_Sensor.pdf	New from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW Edge Spill	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval	71SO_Overfill_Prevention_Valve.pdf	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin STP AG Series	Manufacturer Approval	FFS-0513+Fuel+Compatibility+Reference+Guide+01-17.pdf	
Dispenser	Wayne Flex Dispenser	Manufacturer Approval	Wayne+Ovation+EB23.pdf	
Nozzle	OPW-Nozzle	Manufacturer Approval	OPW-series-nozzles.pdf	
Hose	Continental Conintech	Manufacturer Approval	Continental ContiTech -E8 5Hose.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
All Gasket by Tank Manufacturer	Glasteel II	Manufacturer Approval	Glasteel II Brochure_2.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gasolia E85 Dope	Gasolia	Manufacturer Approval	Gasolia Compatibility.pdf	

Correspondence Contact

Submitter Name Ravindra Penmatsa
Job Title President
Company America Petropump Services LLC d/b/a Ampsco Services
Phone Number (312) 286-6722
Email ravi@ampsco.net
Contractor License # IL002420

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.