



**Veeder-Root Company**

125 Powder Forest Drive  
 Post Office Box 2003  
 Simsbury, CT 06070  
 USA  
 Tel: 860-651-2700  
 Fax: 860-651-2719  
[www.veeder.com](http://www.veeder.com)

September 23, 2015

Subject: Veeder-Root Fuel Compatibility Statement

Veeder-Root Company equipment is compatible with the percent content of the listed alternative fuels.

Equipment Type	Series or Part Number (P/N)	Ethanol %	Biodiesel % ASTM 6751 ASTM 7467
Magnetostrictive Probe	Mag Plus Series 8463XX, Mag Series 8473XX	15%	100%
Tall Tank Probe	Mag-FLEX 889560-XXX, MAGXL-XXX	90%	100%
Continuous Interstitial Tank System	P/N 857280-100, 857280-200, 857280-30X	15%	20%
Electronic Line Leak Detector	Series 8484, 8590	15%	100%
Ground Water Monitoring	P/N 794380-621, 794380-622, 794380-624	15%	20%
Interstitial and Secondary Containment Monitoring	P/N 794380-XXX, 794390-XXX, 847990-00X, 857080-XXX	15%	20%
Interstitial and Secondary Containment Monitoring	P/N 794380-321, 794380-323, 794380-333, 794380-344, 794380-345, 794380-351, 794380-430	85%	20%
Interstitial and Secondary Containment Monitoring	794380-344, 794380-345, 794380-321, 794380-351	85%	100%
Vapor Monitoring	P/N 394390-700	15%	20%
Red Jacket Maxxum Pump	410763-XXX (MXP300JX-XXX or MXP500JX-XXX)	20%	100%

Note: "X" can be substituted for any value.

Compatibility has been determined by testing, industry research and/or engineering judgement.

Regards,

---

Dale Spence  
 Director, Global ATG Products  
 Veeder-Root Company  
 Tel: 860-651-2721  
 Fax: 860-651-2719