



### Blended Fuel Compatibility Form

Facility - 4046693

**Facility Name** Casey's General Store #3754  
**Address** 1161 State Route 54 West  
 Clinton, IL 61727-2147  
**County** Dewitt  
**Contact Name** Jill Reams-Widder  
**Phone Number** (515) 965-6238

Tank - 5

**Tank Material** Fiberglass Double Wall  
**Tank Capacity** 8,000  
**Tank Product** E-85  
**Tank Install Date** 9/20/2018

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech S175SC	Manufacturer Approval		

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump, LMM3617 Dispenser sump	Franklin Fueling APT	Manufacturer Approval		

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root TLS 450 794380-345	Manufacturer Approval		
ATG Probe	Veeder Root TLS 450 846391-4XX	Manufacturer Approval		

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root TLS 450 DPLLD	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root TLS 450, 794380-208	Manufacturer Approval		

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	EBW 705 Defender	Manufacturer Approval		

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Fueling EBW Defender	Manufacturer Approval		

### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible pump, dispensers, ball valve, hoses, nozzles, shear valves	FE Petro, Gilbarco, Morrison, Flexsteel, OPW, EBW	Manufacturer Approval		

### Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

### Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

#### Correspondence Contact

**Submitter Name** Tom Oltman

**Job Title** General Manager

**Company** Total Petroleum Service Co

**Phone Number** (130) 925-1973

**Email** Tom.Oltman@TotalPetroleum.net

**Contractor License #** IL1079

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.