

**Blended Fuel Compatibility Form**

Facility - 2010056

Facility Name Posen Shell
Address 3033 W. 147th Street
Posen, IL 60469
County Cook
Contact Name Robin Thomas
Phone Number (708) 897-8245

Tank - 5

Tank Material Composite Double Wall
Tank Capacity 4,000
Tank Product E85
Tank Install Date 7/17/2007

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel II	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		
Shear Valve	10 Series	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo Sump	Manufacturer Approval		
Single Wall UDC Sump	Bravo Sump	Lab Certification		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors	794380-303 Sensor	Manufacturer Approval		
ATG Probe	846391-407 Probe	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	STP MLDAG	Manufacturer Approval		
Sump Sensor in Single Wall STP/Tanktop Sump	794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 2100	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Fe Petro	Manufacturer Approval		
Nozzle	OPW 11BPE85	Manufacturer Approval		
Hose	Continental Hose	Manufacturer Approval		
Swivel	OPW 241TPS	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gasola Pipe Dope	Gasola Thread Sealent	Manufacturer Approval		

Correspondence Contact

Submitter Name BIlly Umphrey
Job Title President
Company Big Daddy Pump & Compliance
Phone Number (352) 901-4467
Email bigdaddypumpco@gmail.com
Contractor License # IL002457

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.