

**Blended Fuel Compatibility Form**

Facility - 6000527

Facility Name Scott AFB - Building 1575
Address 375th CES/CEV
701 Hangar Road
Scott AFB, IL 62225
County St. Clair
Contact Name Christopher Carlisle
Phone Number (618) 256-2092

Tank - 109

Tank Material Composite Double Wall
Tank Capacity 10,000
Tank Product E-85
Tank Install Date 2/3/1999

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Certificate of Compliance	Underwriters Laboratories Inc.	Lab Certification		
Composite Double Wall	Glasteel II	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall OPW Pisces	OPW/FlexWorks	Manufacturer Approval		
FlexWork's Flexible Piping Installation Instructions	Installation Instructions	Manufacturer Approval		
Chart Stating Compatibility from Petroleum Equipment Institute	Pipe Manufacturer Compatibility with Ethanol Blends	Lab Certification		www.pei.org/ust-component-compatibility-library
Product Compatibility Chart	Morrison Bros. Co.	Manufacturer Approval		
Flexible Double Wall	OPW Flexworks	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Bravo Systems	B4XX	Lab Certification		See page 2 for information
Single Wall STP/Tanktop Sump	Bravo Systems / B4XX	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mag Plus 0.1 GPH In-TANK Probes for Alternative Fluids, no Water Detection, UL	P/N 846391-407	Manufacturer Approval		See page 2 for information
2-Wire C.L. Discriminating Interstitial Sensor	Veeder Root / TLS-350 Series, Interstitial/Liquid Sensor Interface Module, 8 sensor input, P/N 329358-001	Manufacturer Approval		Please let me know if I've misidentified what you need and help me to better und...
Interstitial Sensor 794380-345	Veeder-Root TLS-350	Manufacturer Approval		page 11 of the attached

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 848480-002	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Morrison Bros Overspill Containment	515/516/517/518	Manufacturer Approval		See page 3 for information
Single Wall Spill Bucket Horizontal Cabinet	Veeder Root TLS-350	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	Veeder Root TLS-350	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dispenser	Wayne / Reliance G6200	Manufacturer Approval		
Petroleum Pump Motor Assembly	Franklin Fueling Systems / STP AGR75-VL2-14 / UL483A	Manufacturer Approval		
Checklist For Determining UST System Compatibility	N/A	Manufacturer Approval		Completed checklist for documenting UST system compatibility

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Joseph Weber
Job Title Tanks Program Manager
Company USAF
Phone Number (618) 256-2046
Email joseph.weber.16@us.af.mil

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.