

**Blended Fuel Compatibility Form**

Facility - 5000234

Facility Name Circle K #1423
Address 1801 North Grand East
Springfield, IL 62702
County Sangamon
Contact Name Sotre Manager
Phone Number (217) 523-1984

Tank - 11

Tank Material Fiberglass Brine Filled Double
Wall
Tank Capacity 5,000
Tank Product E-15
Tank Install Date 6/16/2006

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	Containment Solutions	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	NOV Fiberglass Systems / Dualoy 3000 LCX	Manufacturer Approval		See description section, first paragraph, last sentence for compatibility inform...
Shear Valves	EMCO Wheaton Retail / A0060 Stainless	Manufacturer Approval		
Flex Connectors	OPW / FC20 Stainless Flex Connector	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	OPW / Single Walled Sump	Manufacturer Approval		
Under Dispenser Containment	OPW / Pisces	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors	Veeder Root / 794380-303	Manufacturer Approval		
ATG Probe	Veeder Root / Stainless Steel Mag Probe Plus	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root / PLLD	Manufacturer Approval		
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root / 794380-351	Manufacturer Approval		
Under dispenser containment leak detection	Veeder Root / 794380-321	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW / Edge Double Walled Spill Container	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Red Jacket / STP for Alternative Fuels AGP75S1 RJ1	Manufacturer Approval		
Dispenser	Gilbarco / Encore 700	Manufacturer Approval		
Nozzle	Husky / EX E85	Manufacturer Approval		
Dispenser Hoses	Husky / Eagle Flex 3/4 inch hose	Manufacturer Approval		
Breakaway	Husky / E85 Safe-t-break	Manufacturer Approval		
Swivel	Husky / E85 Swivel 6350	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Brian Niederschmidt

Job Title Estimator

Company Neumayer Equipment, Inc.

Phone Number (636) 515-4517

Email brian_niederschmidt@neumayerequipment.com

Contractor License # IL1502

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.