

**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL****Blended Fuel Compatibility Form**

Facility - 2000751

Facility Name 3501 S. Central, LLC
Address 3501 S. Central Ave.
Cicero, IL 60650
County Cook
Contact Name Ahmad Zahdan
Phone Number (708) 372-7632

Tank - 6

Tank Material Tank - Composite Double
Wall Glasteel II
Tank Capacity 5,000
Tank Product E-85
Tank Install Date Not Installed

Tank Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--|--------------------|-----------------------|----------------------|-------------------------|
| Tank - Composite Double Wall Glasteel II | Glasteel II | Manufacturer Approval | E85 glass steel 2... | From Permit Application |

Piping Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|---|--------------------|----------------------|----------------------|-------------------------|
| Piping - Flexible Double Wall OPW Flexworks | OPW Flexworks | Lab Certification | E85 opw flexworks... | From Permit Application |
| Piping - Flex Connector Steel | Franklin Fueling | Lab Certification | e85 franklin all... | From Permit Application |
| Piping - Ball Valves | Franklin Fueling | Lab Certification | e85 franklin all... | From Permit Application |
| Piping - Shear Valves | OPW | Lab Certification | e85 opw.pdf | From Permit Application |

Containment Sump Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|---------------------------------------|--------------------|-----------------------|---------------|-------------------------|
| Piping - Single Wall STP/Tanktop Sump | Bravo | Manufacturer Approval | e85 bravo.pdf | From Permit Application |

Release Detection Tank Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------|--------------------|----------------------|----------------------|---------|
| ATG Probe | Veeder Root | Lab Certification | e85 veeder probe.... | |

Release Detection Piping Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--|------------------------|----------------------|----------------------|-------------------------|
| Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown | Veeder Root 794380-345 | Lab Certification | e85 veeder sensor... | From Permit Application |
| Leak Detect - Piping - Electronic Pressurized Line Leak Detection | Veeder root | Lab Certification | e85 veeder PLLD.p... | From Permit Application |

Spill Prevention Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------|--------------------|----------------------|---------------|---------|
|--------------------|--------------------|----------------------|---------------|---------|

| | | | | |
|---|-------------------------------|-------------------|------------------|-------------------------|
| Spill Contain Device - Double Wall Spill Bucket | FE Petro Defender 705994/203K | Lab Certification | e85 franklin.pdf | From Permit Application |
|---|-------------------------------|-------------------|------------------|-------------------------|

Overfill Prevention Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|---|--------------------|----------------------|---------------|-------------------------|
| Overfill Prev Device - Overfill Drop Tube Valve | OPW 71SOM-412C | Lab Certification | e85 opw.pdf | From Permit Application |

Pump Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------|--------------------|----------------------|-----------------|---------|
| Wayne | Ovation II | Lab Certification | e85 ovation.pdf | |

Gaskets & Seals Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--|--------------------|----------------------|---------------|--|
| None that are not part of an approved device | None | Not Applicable | e85 dope.pdf | None that are not part of an approved device |

Joint Dopes & Adhesives Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------|--------------------|----------------------|---------------|---------|
| Gasola E Seal | Gasola E Seal | Lab Certification | e85 dope.pdf | |

Correspondence Contact

Submitter Name Stephen Kryl
Job Title Project Manager
Company Stephen Kryl
Phone Number (708) 243-9081
Email steve@andersonpump.com
Contractor License # IL002275

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.