



### Blended Fuel Compatibility Form

Facility - 2046456

<b>Facility Name</b>	Pilot Travel Center
<b>Address</b>	1050 Busse Road Bensenville, IL 60106
<b>County</b>	Du Page
<b>Contact Name</b>	Debbie Versillo
<b>Phone Number</b>	(630) 521-0218

Tank - 4

<b>Tank Material</b>	Fiberglass Double Wall
<b>Tank Capacity</b>	20,000
<b>Tank Product</b>	B-99
<b>Tank Install Date</b>	8/28/2017

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Ball Valves	Ferguson Ball Valves	Manufacturer Approval		
Fiberglass Double Wall	NOV / Red Thread IIA	Manufacturer Approval		

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Piping/Tanktop Sump	Petroleum Containment, Inc Sump	Manufacturer Approval		
Single Wall Blender Piping Sump	Petroleum Containment, Inc Sump	Manufacturer Approval		
Single walled Bioheater Tank Top Sump	Petroleum Containment, Inc.	Manufacturer Approval		

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root / 0794380-345	Manufacturer Approval		
ATG Probe	Veeder Root / 846391 Mag Plus Probe	Manufacturer Approval		

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Suction Piping Tank Top Sensor	Veeder Root / 0794380-321	Manufacturer Approval		
Blender Sump Sensor	Veeder Root / 0794380-321	Manufacturer Approval		
Bio-heater Tank Top Sump Sensor	Veeder Root / 0794380-321	Manufacturer Approval		

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW / Edge Double Walled Spill Container	Manufacturer Approval		

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW / 71SO-410CB	Manufacturer Approval		

#### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Suction Pump	Gorman Rupp	Manufacturer Approval		

#### Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

#### Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

#### Correspondence Contact

**Submitter Name** Brian Niederschmidt

**Job Title** Estimator

**Company** Neumayer

**Phone Number** (636) 515-4517

**Email** brian\_niederschmidt@neumayerequipment.com

**Contractor License #** IL1502

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.