



Blended Fuel Compatibility Form

Facility - 1043101		Tank - 2	
Facility Name	Thorntons #364	Tank Material	Fiberglass Brine Filled Double Wall
Address	102 West Etna Road Ottawa, IL 61350	Tank Capacity	12,000
County	LaSalle	Tank Product	E85
Contact Name	Renee Miller	Tank Install Date	3/2/2006
Phone Number	(815) 433-4101		

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	XERXES	Manufacturer Approval	Xerxes Compatibility.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Shear Valve	OPW 10P0152E85	Manufacturer Approval	Compat. OPW Shear Valve.p df	OPW Shear Valve
Flexible Double Wall	OPW Flexworks	Manufacturer Approval	OPW pipe.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Bravo UDC's	Bravo	Lab Certification	Compat Bravo UDC.pdf	
Single Wall STP/Tanktop Sump	Xerxes	Manufacturer Approval	Compat. Xerxes STP sump.p df	Re-use of existing STP sump (Xerxes Fiberglass)Re-use of existing UDC's) This s...
Single Wall UDC Sump	Bravo	Manufacturer Approval	Bravo sump.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root/ 846397/407	Manufacturer Approval	Compat VR Probes.pdf	
Hydrostatic Reservoir Interstitial Monitoring Sensors	Veeder Root/ 794380-301	Manufacturer Approval	Compat VR Sensors.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root/ DPLLD 332972-008	Manufacturer Approval	Compat VR DPLLD.pdf	
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	veeder Root	Manufacturer Approval	VR Sensors.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Franklin Fueling	Manufacturer Approval	FF bucket and tube.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW	Manufacturer Approval	OPW 7150 droptube.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Franklin Fueling/ ISTM2-15	Manufacturer Approval	Fuel Compat FE STP.pdf	
Dispenser hose	Husky	Manufacturer Approval	Compat. Husky Hose Kit.pdf	Complete hanging hardware kits- E85 Compat.

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasola/ GE16	Manufacturer Approval	Compat. Gasola GE16.pdf	
Fiberglass Adhesive	Ameron	Manufacturer Approval	Compat. NOV.Ameron.pdf	

Correspondence Contact

Submitter Name James Franklin
Job Title Construction Manager
Company Seneca Companies
Phone Number (515) 601-6635
Email jfranklin@senecaco.com
Contractor License # IL598

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.