



Blended Fuel Compatibility Form

Facility - 2046754

| | |
|----------------------|--|
| Facility Name | Woodman's Car Wash |
| Address | 27555 Illinois Route 120 Lakemoor, IL 60051 |
| County | McHenry |
| Contact Name | Deb Arnold |
| Phone Number | (608) 754-8382 |

Tank - 5

| | |
|--------------------------|------------------------|
| Tank Material | Fiberglass Double Wall |
| Tank Capacity | 6,000 |
| Tank Product | E85 |
| Tank Install Date | 9/24/2020 |

Tank Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|------------------------|--------------------|-----------------------|------------------|---------|
| Fiberglass Double Wall | XERXES | Manufacturer Approval | Xerxes Tanks.pdf | |

Piping Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|----------------------|--|-----------------------|---|---------|
| Flexible Double Wall | Franklin Fueling Systems UPP | Manufacturer Approval | FFS-0164 UPP Semi-Rigid P ipework System Datasheet. pdf | |
| Shear Valve | E85 OPW compatibility10 series emergency valve | Manufacturer Approval | OPW Shear Valve.pdf | |

Containment Sump Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|------------------------------|---------------------------------|-----------------------|-------------------------------------|---------|
| Single Wall STP/Tanktop Sump | Bravo_Sumps_AlternativeFuels_R3 | Manufacturer Approval | Bravo_Sumps_AlternativeFuels_R3.pdf | |
| Single Wall UDC Sump | Bravo_Sumps_AlternativeFuels_R3 | Manufacturer Approval | Bravo_Sumps_AlternativeFuels_R3.pdf | |

Release Detection Tank Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--|--------------------|-----------------------|------------------------------------|---------|
| Non-Discriminating Interstitial Monitoring Sensors | E85 EVO Incon | Manufacturer Approval | E85+EVO+Incon+Probes+&+Sensors.pdf | |
| ATG Probe | E85 EVO Incon | Manufacturer Approval | E85+EVO+Incon+Probes+&+Sensors.pdf | |

Release Detection Piping Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--|--------------------|-----------------------|------------------------------------|---------|
| Electronic Pressurized Line Leak Detection | Franklin EVO LS500 | Manufacturer Approval | E85+EVO+Line+Leak.pdf | |
| Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | Franklin EVO Incon | Manufacturer Approval | E85+EVO+Incon+Probes+&+Sensors.pdf | |

Spill Prevention Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------------|--------------------|-----------------------|-------------------------------------|---------|
| Single Wall Spill Bucket | Bravo | Manufacturer Approval | Bravo_Sumps_AlternativeFuels_R3.pdf | |

Overfill Prevention Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------------|--------------------|-----------------------|-------------------------------------|---------|
| Overfill Drop Tube Valve | OPW 71SOM | Manufacturer Approval | 71SOM_Overfill_Prevention_Valve.pdf | |
| Overfill Alarm | E85 EVO Incon | Manufacturer Approval | E85+EVO+Incon+Probes+&+Sensors.pdf | |

Pump Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------------|-----------------------|-----------------------|--------------------------------|---------|
| Submersible Turbine Pump | Franklin STPAG150-VL2 | Manufacturer Approval | FE Petro Submersible Pump .pdf | |
| Nozzle | OPW | Manufacturer Approval | E85+Compat+Nozzle.pdf | |
| Hose | Flexsteel Futura | Manufacturer Approval | E85+Compat+hose.pdf | |

Gaskets & Seals Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------|----------------------|-----------------------|----------------------------|---------|
| Gaskets and Seals | Wayne Ovation EB23/5 | Manufacturer Approval | Pages from 2046754+(1).pdf | |

Joint Dopes & Adhesives Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|-------------------------|--------------------|-----------------------|---------------|---------|
| Joint Dopes & Adhesives | Gasoil E-Seal | Manufacturer Approval | Gasoil.pdf | |

Correspondence Contact

Submitter Name Amber Pena
Job Title Service Manager
Company Stenstrom Petroleum Services Group
Phone Number (815) 398-6250
Email amberp@rstenstrom.com
Contractor License # IL1890

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.