



Blended Fuel Compatibility Form

Facility - 4013753

Tank - 30

Facility Name	Pilot Travel Center #171-02	Tank Material	Fiberglass Double Wall
Address	503 N. Oakwood Street Oakwood, IL 61858	Tank Capacity	20,000
County	Vermilion	Tank Product	B-99
Contact Name	Joshua Binkluy	Tank Install Date	5/8/2013
Phone Number	(217) 354-4270		

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Blender Piping Sump	NEF Tank Top Sump	Manufacturer Approval		
Single Wall Bio Heater Tank Top Sump	OPW Fiberglass	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root / 846390 -109 Mag Probe	Manufacturer Approval		
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root / 0794380-345	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root / 0794380-321	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW / Edge Double Walled Spill Container	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW / 71SO-410CB	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Suction Pump	Gorman Rupp	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Skip Aulgur

Job Title Estimator

Company Neumayer Equipment Co

Phone Number (314) 497-9884

Email skip_aulgur@neumayerequipment.com

Contractor License # IL1502

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.