

**Blended Fuel Compatibility Form**

Facility - 5013936

Facility Name Jiffi Stop #586
Address 1401 North 24th Street
Quincy, IL 62301
County Adams
Contact Name Rolfe Lann
Phone Number (804) 730-1563

Tank - 6

Tank Material STIP3 Single Wall
Tank Capacity 2,000
Tank Product E-85
Tank Install Date 9/1/1984

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STIP3 Single Wall	N/A	Manufacturer Approval		TANK IS A STIP3 STEEL. THE MANUFACTURE OF THE TANK IS UNKNOWN

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Galvanized Steel Single Wall Piping	N/A	Manufacturer Approval		PIPE IS GALV STEEL THE MANUFACTURE UNKNOWN

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
NONE	N/A	Not Applicable		NO STP SUMP

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
VEEDER ROOT TANK MONITOR	TLS 450	Manufacturer Approval		
ATG Probe	846397-4XX Stainless Steel VEEDER ROOT	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
European with No Test Req Suction	N/A	Not Applicable		N/A
Piping Sump Sensors Not Regulated Not Installed in Not Installed STP/Tanktop Sump	N/A	Not Applicable		N/A

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	1-2100 SERIES OPW	Manufacturer Approval		OPE 1-2100 SERIES

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 61S0M	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
TOKHEIM CAST IRON SUCTION PUMP	TOKHEIM 262A	Not Applicable		NO INFORMATION ON THIS PUMP NO LONGER IN BUSINESS IS ALL CAST IRON METER AND PUM...

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name KEVIN MAJORS
Job Title SERVICE MANAGER
Company RL HOENER
Phone Number (217) 223-2190
Email KMAJORS@RLHOENER.COM
Contractor License # IL2021

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.