

**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL****Blended Fuel Compatibility Form**

Facility - 2032952

Facility Name Faust Inc Dba Abc
Automotive Electronic
Address 4755 W Grand
Chicago, IL 60639
County Cook
Contact Name Faust James
Phone Number (708) 788-0200

Tank - 6

Tank Material N/A
Tank Capacity 4,000
Tank Product E-85
Tank Install Date Unknown

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel II	Lab Certification	Glasteel II Brochure_2.pdf	From Permit Application

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
OPW	OPW Flexworks	Lab Certification	OPW-Fuel+Compatibility+Matrix+(Below+Ground) (12).pdf	From Permit Application
Flex Connector Steel	Hose Master	Lab Certification	Hose Master E85 Compatibility 2018.pdf	From Permit Application
Ball Valves	jomar	Lab Certification	JOMAR SS ball valve.pdf	From Permit Application
Shear Valves	Opw 10P-0152E85	Lab Certification	OPW-Fuel+Compatibility+Matrix+(Below+Ground) (12).pdf	From Permit Application

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo	Lab Certification	Bravo Sumps.pdf	From Permit Application
OPW	Loop System	Lab Certification	OPW-Fuel+Compatibility+Matrix+(Below+Ground) (12).pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 794380-430	Lab Certification	Veeder Root Sensors.pdf	From Permit Application
ATG Probe	Veeder Root 846397-409	Lab Certification	Magnetostrictive Probes.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 859080-001	Lab Certification	Veeder Root Sensors.pdf	From Permit Application
Non-Discriminating Sump Sensor with positive shutdown	Veeder Root 794380-323	Lab Certification	Veeder Root Sensors.pdf	From Permit Application

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Defenders 705555111CI-GKT	Lab Certification	Defender spill bucket Franklin.pdf	From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Lab Certification	OPW-Fuel+Compatibility+Matrix+(Below+Ground) (12).pdf	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Wayne	Ovation	Lab Certification	Wayne Ovation Compatibility.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Caps and Rings	veeder root	Lab Certification	Cap and Ring E85 Compatibility.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gaseola e seal	Lab Certification	Gaseola Pipe dope.pdf	

Correspondence Contact

Submitter Name Hoyt Ary
Job Title Project Manager
Company Anderson Pump service
Phone Number (708) 906-6178
Email hoyt@andersonpump.com
Contractor License # IL002275

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.