



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 2047066

Facility Name Construction/Future
Maintenance Facility
Address 830 Thomas Drive
Bensenville, IL 60106
County Cook
Contact Name
Phone Number

Tank - 7

Tank Material Tank - Fiberglass Brine
Filled Double Wall XERXES
Tank Capacity 10,000
Tank Product E-85
Tank Install Date 8/28/2020

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Tank - Fiberglass Brine Filled Double Wall XERXES	XERXES Fiberglass	Manufacturer Approval	M-16 Xerxes tank ...	From Permit Application

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX	Ameron Fiberglass Dualoy 3000/LCX	Manufacturer Approval	M-16 NOV product ...	From Permit Application
Piping - Flex Connector Steel	Hosemaster	Manufacturer Approval	M-16 Flex connect...	From Permit Application
Piping - Other Submersible Pump	Submersible	Manufacturer Approval	M-16 Red Jacket E...	From Permit Application
Piping - Shear Valves	OPW 10	Manufacturer Approval	M-16 spill and ov...	From Permit Application

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping - Single Wall STP/Tanktop Sump	Bravo B7000 series dispenser sump and associated accessories	Manufacturer Approval	M-16 Dispenser su...	From Permit Application

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors	Veeder Root sensor model 794380-323	Manufacturer Approval	M-16 Veeder Root ...	From Permit Application
ATG Probe	Veeder Root Probe 846391	Manufacturer Approval	M-16 Veeder Root ...	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Leak Detect - Piping - Electronic Pressurized Line Leak Detection	Veeder Root 848480	Manufacturer Approval	M-16 Veeder Root ...	From Permit Application
Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown	Veeder Root 794380-323	Manufacturer Approval	M-16 Veeder Root ...	From Permit Application

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Spill Contain Device - Double Wall Spill Bucket	OPW 1-3100 series	Manufacturer Approval	M-16 spill and ov...	From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Prev Device - Overfill Drop Tube Valve	OPW 71SOM	Manufacturer Approval	M-16 spill and ov...	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Red Jacket submersible pump[	Red Jacket AGP200S1	Manufacturer Approval	M-16 Red Jacket E...	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Wayne Dispenser	Wayne E3G7203D	Manufacturer Approval	M-16 Wayne dispen...	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe dope	Gasolia E-Seal	Manufacturer Approval	M-16 pipe dope E...	

Correspondence Contact

Submitter Name Jason Reed
Job Title Project Manager
Company Jason Reed
Phone Number (630) 878-6354
Email jasonr@rstenstrom.com
Contractor License # IL1890

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.