

**Blended Fuel Compatibility Form**

Facility - 2019889

Facility Name Citgo Gas Station
Address 3202 W. Cermak Rd.
Chicago, IL 60623
County Cook
Contact Name James Mathai
Phone Number (773) 521-6700

Tank - 3

Tank Material Steel Single Wall
Tank Capacity 6,000
Tank Install Date Unknown
Current Product on File Diesel Fuel
Newly Reported Product E-85

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Steel Single Wall	Steel	Not Applicable		Per Steel Tank Institute steel is a compatible material with Ethanol product.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall	A.O. Smith	Manufacturer Approval	ameron fiberglass...	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP/Tanktop Sump	Franklin Fueling, TSM-4245	Manufacturer Approval	franklin poly sum...	
Single Wall Dispenser Sump	Franklin Fueling, LMM-3914-36-w	Manufacturer Approval	franklin poly sum...	
Pipe Entry Boots	OPW EBF-0200 & EBF-0200F	Manufacturer Approval	opw all products....	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846391-507	Manufacturer Approval	veeder root probe...	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Line Leak Detection	Franklin Fueling / Red Jacket Fx1	Manufacturer Approval	red jacket mllld.p...	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1-2100EVR	Manufacturer Approval	opw all products....	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval	opw all products....	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Franklin 4020159	Manufacturer Approval	franklin stp.pdf	
Dispenser	Wayne EB23/5220D3	Manufacturer Approval	wayne dispensers ...	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Ed Angell

Job Title Project Manager

Company B&K Equipment Company

Phone Number (170) 826-9807

Email ed@bkequip.com

Contractor License # IL1207

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.