

**Blended Fuel Compatibility Form**

Facility - 2025082

Facility Name Posen Gas & Food
Address 2700 W. 147th Street
Posen, IL 60469
County Cook
Contact Name Mohammed Ali
Phone Number

Tank - 4

Tank Material Composite Double Wall
Tank Capacity 2,000
Tank Product E85
Tank Install Date 12/24/1996

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Lannon Tank	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron LCX	Manufacturer Approval		
Shear Valve	OPW, 10P	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Containment Solutions	Manufacturer Approval		
Single Wall UDC Sump	OPW, Pisces series	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root, 794380-430	Manufacturer Approval		
ATG Probe	Veeder Root, 846397-407	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Franklin 403169901	Manufacturer Approval		
Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1-2100EVR	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Fueling, Defender	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin 4020159	Manufacturer Approval		
Dispenser	Wayne EB23/5220D3	Manufacturer Approval		
Nozzle	OPW, 11BP-0992-E85	Manufacturer Approval		
Hose	Continental, Futura Etan-all	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact	
Submitter Name Ed Angell Job Title Project Manager Company B&K Equipment Company Phone Number (708) 474-3344 Email ed@bkequip.com Contractor License # IL1207	☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.