



Blended Fuel Compatibility Form

Facility - 2018605

Facility Name	Morris Travel Center
Address	21 Romines Drive Morris, IL 60450
County	Grundy
Contact Name	Donna Barnard
Phone Number	(309) 261-2066

Tank - 19

Tank Material	Tank - Fiberglass Double Wall Containment Solutions
Tank Capacity	20,000
Tank Product	B-99
Tank Install Date	Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	Containment-Solutions com patibility Letter.pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Fiberglass	Manufacturer Approval	10-NOV.pdf	New from Permit Application.

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo B487-48-S-02	Manufacturer Approval	15-Bravo_Sumps_Alternativ eFuels_R3.pdf	New from Permit Application.
Single Wall Transition Sump	Bravo	Manufacturer Approval	15-Bravo_Sumps_Alternativ eFuels_R3.pdf	New from Permit Application.

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Interstice Sensor	VeederRoot 794380-304	Manufacturer Approval	304 Sensor.pdf	
ATG Probe	VeederRoot 846397-110	Manufacturer Approval	18-Veeder-Root Fuel Compa tibility Letter - Execute d - 2015-09- 23.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	FE Petro - STP- MLD+BD403171901	Manufacturer Approval	FE Leak.pdf	New from Permit Application.
Sump Sensor with positive shutdown	VeederRoot 794380-351	Manufacturer Approval	18-Veeder-Root Fuel Compa tibility Letter - Execute d - 2015-09- 23.pdf	New from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1C-3122D	Manufacturer Approval	OPW Compatibility BUCKET. pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SP-B	Manufacturer Approval	OPW Compatibility OPV.pdf	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	FE PETRO 2HP AG	Manufacturer Approval	FFS-0796 Submersible Turbine Pumps Datasheet.pdf	
Dispenser	Gilbarco	Manufacturer Approval	13-Encore UL Approval_Bio Diesel.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Entry Boot w Seal	Bravo	Manufacturer Approval	16-Bravo_Fittings_AlternativeFuels_R3.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasolia - Hard Set	Manufacturer Approval	11-GASOILA-TDS-hard-set.pdf	

Correspondence Contact**Submitter Name** Nate Lawrence**Job Title** VP Operations**Company** Lawrence Building Corporation**Phone Number** (260) 469-8400**Email** nlawrence@lawrencebuilding.com**Contractor License #** IL002416
 By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.