

**Blended Fuel Compatibility Form**

Facility - 2022728

Facility Name Gas for Less
Address 5035 S. Western Ave.
Chicago, IL 60609
County Cook
Contact Name Ahmed Zubair
Phone Number (630) 460-3813

Tank - 6

Tank Material Tank - Composite Double
Wall Glasteel II
Tank Capacity 6,000
Tank Product E85
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel II	Manufacturer Approval	Glasteel II BioFuels Compatibility 2018.pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	NUPI Smartflex	Manufacturer Approval	NUPI UL LETTER - COMPATIBILITY.pdf	New from Permit Application.
Shear Valve	OPW 10 PLUS	Manufacturer Approval	OPW 10 Plus Impact Compatibility.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	BRAVO B 421	Manufacturer Approval	Bravo Sump Compatibility Statement.pdf	New from Permit Application.
Not Installed UDC Sump	NUPI HDPE	Manufacturer Approval	NUPI UL LETTER - COMPATIBILITY.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
INTERSTITIAL SENSOR	VEEDER ROOT 794380-430	Manufacturer Approval	Veeder Root Sensor Compatibility Statement.pdf	
ATG Probe	VEEDER ROOT 846391-409	Manufacturer Approval	Veeder Root E85 probe 577 013-054.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Other check valve	FE PETRO 403169901 STP-MLD+AG	Manufacturer Approval	FE Petro MLD Compatibility.pdf	New from Permit Application.
Sump Sensor with positive shutdown	VEEDER ROOT 794380-323	Manufacturer Approval	Veeder Root Sensor Compatibility Statement.pdf	New from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	FE PETRO DEFENDER	Manufacturer Approval	FE PETRO DEFENDER ffs-013 0-defender-series-brochure-713-web.pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM	Manufacturer Approval	OPW Belowground Product C ompatibility Listing 0715 18.pdf	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	FE PETRO STPAP150-VL2	Manufacturer Approval	FE PETRO STPAPM200-VL2 ff s-0412-60-hz-advanced-pro tection-submersible-turbi ne-pumps-datasheet.pdf	
Dispenser	WAYNE OVATION	Manufacturer Approval	WAYNE MH1821-45-6 Ovation CertificateofCompliance. pdf	
Nozzle	OPW 11 A	Manufacturer Approval	OPW 11a-and-11b-automatic -nozzles.pdf	
Hose	GOODYEAR	Manufacturer Approval	Goodyear E85 Ethanol hose .pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
NA	NA	Not Applicable		NA

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
PIPE DOPE	GASOILA E SEAL	Manufacturer Approval	Gasola E-Seal.pdf	

Correspondence Contact

Submitter Name Chris Derro
Job Title President
Company Cardinal Compliance LLC
Phone Number (708) 717-2676
Email cderro@cardinalcompliance.net
Contractor License # IL002418

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.