



### Blended Fuel Compatibility Form

<b>Facility - New</b>		<b>Tank - 6</b>	
<b>Facility Name</b>	GCS / BP	<b>Tank Material</b>	Tank - Fiberglass Double Wall Containment Solutions
<b>Address</b>	107 E. Stagecoach Trail Yorkville, IL 60560	<b>Tank Capacity</b>	10,000
<b>County</b>	Kendall	<b>Tank Product</b>	E-85
<b>Contact Name</b>	Thomas Williamson	<b>Tank Install Date</b>	Not Installed
<b>Phone Number</b>	(847) 826-0660		

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	CSI Compatibility Statement.pdf	From Permit Application

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	NUPI Smartflex	Manufacturer Approval	NUPI UL LETTER - COMPATIBILITY.pdf	From Permit Application
Other Pump	Submersible	Manufacturer Approval	FE Petro STP Compatibility Statement.pdf	From Permit Application
Shear Valves	OPW 10P Series	Manufacturer Approval	OPW 10 Plus Impact Compatibility.pdf	From Permit Application

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Containment Solutions SW STP Sump	Manufacturer Approval	CSI alcohol compatibility statement 9-25-03.pdf	From Permit Application
Single Wall UDC's	NUPI	Manufacturer Approval	SMFX SUMPS E85 declaration_NA.pdf	

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors With Monitor	Veeder Root Dry Interstice	Manufacturer Approval	Veeder Root Sensor Compatibility Statement.pdf	From Permit Application
ATG Probe	Veeder Root Root Alternative Fuels	Manufacturer Approval	Veeder Root E85 probe 577 013-054.pdf	

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root DPLLD	Manufacturer Approval	Veeder Root PLLD_DPLLD Fuel Compatibility.pdf	From Permit Application
Non-Discriminating Sump Sensor with positive shutdown	Veeder Root 323	Manufacturer Approval	Veeder Root Sensor Compatibility Statement.pdf	From Permit Application

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Franklin Defender SW Bucket	Manufacturer Approval	ffs-0130-defender-series-brochure-713-web.pdf	From Permit Application

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Defender	Manufacturer Approval	Franklin Defender Series OPV Datasheet.pdf	From Permit Application
Overfill Alarm	Veeder Root	Manufacturer Approval	Veeder Root Sensor Compatibility Statement.pdf	From Permit Application

#### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP's	FE Petro AG Series Submersible Pumps Petro AG Series Submersible Pump	Manufacturer Approval	FE PETRO STPAPM200-VL2 ffs-0412-60-hz-advanced-protection-submersible-turbine-pumps-datasheet.pdf	

#### Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fill Adapter	OPW 61 SALP	Manufacturer Approval	OPW FCS Material Compatibility Matrix 2018 revised 072018.pdf	
Vapor Adapter	OPW 61 VSA	Manufacturer Approval	OPW 61VSA-MA_E85_EVR_Approved_Vapor_Recovery_Swivel_Adaptor.pdf	

#### Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope Sealant	Gasola E Seal	Manufacturer Approval	Gasola E-Seal.pdf	

#### Correspondence Contact

**Submitter Name** Tim Berg  
**Job Title** President  
**Company** Performance Tank, Inc.  
**Phone Number** (847) 612-6551  
**Email** tberg@perftank.com  
**Contractor License #** IL881

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.