

**Blended Fuel Compatibility Form**

Facility - 6044208

Facility Name Greenmount Motomart
Address 1790 Frank Scott Parkway
Shiloh, IL 62269
County St. Clair
Contact Name Jeff Zimmermann
Phone Number (618) 622-8379

Tank - 4

Tank Material Composite Double Wall
Tank Capacity 5,000
Tank Product E85
Tank Install Date 11/5/2008

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Permatank	Manufacturer Approval	Steel Facts No. 2-Biofuel s Compatible v 10.5.11.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	OPW Flexworks C20A	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018 (1).pdf	
Stainless Steel Single Wall Piping	Stainless steel pipe	Lab Certification	Steel Facts No. 2-Biofuel s Compatible v 10.5.11.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall UDC Sumps	OPW DS POLY SUMP	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018 (1).pdf	
Single Wall STP/Tanktop Sump	OPW fiberglass sumps	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018 (1).pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Franklin Fueling FMP-LL3-125	Manufacturer Approval	FFS-0434 Digital Inventory & Leak Detection Probes Datasheet.pdf	
Non-Discriminating Interstitial Monitoring Sensors	Franklin Fueling TSP-ULS	Manufacturer Approval	FFS-0635 Sensors Compatibility Datasheet.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Franklin Fueling LS5000	Manufacturer Approval	FFS-0263 Electronic Line Leak Detection Datasheet.pdf	
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Franklin Fueling TSP-ULS	Manufacturer Approval	FFS-0635 Sensors Compatibility Datasheet.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Franklin Fueling Defender Series	Manufacturer Approval	FFS-0127 Defender Series Spill Containers Datasheet.pdf	Replacing from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Fueling Defender Series	Manufacturer Approval	FFS-0392 Defender Series OPV Datasheet.pdf	Replacing from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submerged Pump	Red Jacket AG	Manufacturer Approval	Red Jacket AG 576047-305 (2).pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact		☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Submitter Name	clay Bayne	
Job Title	project manager	
Company	UPC Enterprises, LC d/b/a United Petroleum Service	
Phone Number	(314) 797-0468	
Email	cbayne@unitedpetro.com	
Contractor License #	IL002402	