

**Blended Fuel Compatibility Form**

Facility - 4007977

Facility Name TA Operating, LLC
Address 505 Trucker Lane
R.R. #7
Bloomington, IL 61701
County McLean
Contact Name Lee Folkens
Phone Number (309) 530-1380

Tank - 9

Tank Material Tank - Fiberglass Double Wall
Fluid Containment Brine
Filled
Tank Capacity 20,000
Tank Product B-99
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Fluid Containment Brine Filled	Manufacturer Approval	Containment-Solutions compatibility Letter.pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Fiberglass	Manufacturer Approval	10-NOV.pdf	New from Permit Application.

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Transition Sump	Bravo	Manufacturer Approval	15-Bravo_Sumps_AlternativeFuels_R3.pdf	New from Permit Application.
Single Wall Tank Sump	Bravo B487-48-S-02	Manufacturer Approval	15-Bravo_Sumps_AlternativeFuels_R3.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Interstice Sensor	VeederRoot 794380-304	Manufacturer Approval	304 Sensor.pdf	
ATG Probe	Veeder-Root 846397-110	Manufacturer Approval	18-Veeder-Root Fuel Compatibility Letter - Executed - 2015-09-23.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	FE Petro - STP-MLD+BD 403171901	Manufacturer Approval	FE Leak.pdf	New from Permit Application.
Sump Sensor with positive shutdown	VeederRoot 794380-351	Manufacturer Approval	18-Veeder-Root Fuel Compatibility Letter - Executed - 2015-09-23.pdf	New from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1C-3122D	Manufacturer Approval	OPW Compatibility BUCKET. pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SO-B	Manufacturer Approval	OPW Compatibility OPV.pdf	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	FE Peto 2HP AG	Manufacturer Approval	FFS-0796 Submersible Turbine Pumps Datasheet.pdf	
Dispenser	Gilbarco	Manufacturer Approval	13-Encore UL Approval_Bio Diesel.pdf	Existing

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Entry Boot w Seal	Bravo	Manufacturer Approval	16-Bravo_Fittings_AlternativeFuels_R3.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasola - Hard Set	Manufacturer Approval	11-GASOILA-TDS-hard-set.pdf	

Correspondence Contact**Submitter Name** Nate Lawrence**Job Title** VP Operations**Company** Lawrence Building Corp**Phone Number** (260) 469-8400**Email** nlawrence@lawrencebuilding.com**Contractor License #** IL002416☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.