

**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL****Blended Fuel Compatibility Form**

Facility - 2046937

Facility Name True North Energy LLC
Address 34692 North Route 83
Grayslake, IL 60030
County Lake
Contact Name Dave Nye
Phone Number (877) 245-9336

Tank - 4

Tank Material N/A
Tank Capacity 6,000
Tank Product E-15
Tank Install Date Unknown

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Tank - Fiberglass Double Wall Containment Solutions	Containment Solutions	Manufacturer Approval	CSI Compatibility...	From Permit Application

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping - Flexible Double Wall Franklin Fueling Systems UPP	Franklin Fueling Systems UPP	Manufacturer Approval	E 15 DOCUMENTATIO...	From Permit Application

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Piping - Single Wall STP/Tanktop Sump	CSI	Manufacturer Approval	CSI Compatibility...	From Permit Application

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors	Veeder Root	Manufacturer Approval	Veeder Root Compa...	From Permit Application
ATG Probe	Veeder Root	Manufacturer Approval	Veeder Root Compa...	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Leak Detect - Piping - Electronic Pressurized Line Leak Detection	Veeder Root	Manufacturer Approval	Veeder Root Compa...	From Permit Application
Leak Detect - Piping - Non-Discriminating Sump Sensor with positive shutdown	Veeder Root	Manufacturer Approval	E 15 DOCUMENTATIO...	From Permit Application

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Spill Contain Device - Single Wall Spill Bucket	OPW	Manufacturer Approval	E 15 DOCUMENTATIO...	From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Prev Device - Overfill Drop Tube Valve	OPW	Manufacturer Approval	E 15 DOCUMENTATIO...	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible	FE Petro	Manufacturer Approval	FE Petro Compatib...	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasoil	Manufacturer Approval	Gasoil Compatibi...	

Correspondence Contact

Submitter Name Warren Cherner
Job Title President
Company Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company
Phone Number (847) 465-4000
Email warren@metrotank.com
Contractor License # IL102

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.