



### Blended Fuel Compatibility Form

Facility - 2006925

**Facility Name** Zainab, Inc.  
**Address** 17945 S. Halsted Street  
 Homewood, IL 60430  
**County** Cook  
**Contact Name** Waseem Ahmed  
**Phone Number** (708) 590-4099

Tank - 7

**Tank Material** Fiberglass Double Wall  
**Tank Capacity** 6,000  
**Tank Product** E85  
**Tank Install Date** 10/11/2008

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval	tank-manufacturer-compatibility.pdf	

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Shear Valve	OPW-10 Series	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	other-equipment-compatibility.pdf	

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo Systems B400	Manufacturer Approval	other-equipment-compatibility.pdf	
Single Wall UDC Sump	Petroleum Containment Inc	Manufacturer Approval	pci-biodiesel.pdf	

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846391-409	Manufacturer Approval	577014-449-08_Stainless_Steel_Mag_Plus_In-Tank_Probe_Alternative_Fluids.pdf	Replaced the probe

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Franklin Fueling-STP-MLD+AG	Manufacturer Approval	FFS-0513+Fuel+Compatibility+Reference+Guide+01-17.pdf	
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root-794380-323	Manufacturer Approval	577013-750-10_Position_Sensitive_Sensor.pdf	Replaced the sensors

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW-2100 Series	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW-71SOM-412C Series	Manufacturer Approval	71SO_Overfill_Prevention_Valve.pdf	

### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin Fueling-STPAG Series	Manufacturer Approval	FFS-0513+Fuel+Compatibility+Reference+Guide+01-17.pdf	
Dispenser	Gilbarco -Encore Series Flex Dispenser	Manufacturer Approval	Encore Flex Fuel Dispense r _ Gilbarco Veeder-Root. pdf	
Nozzle	OPW-11BP-0992-E85	Manufacturer Approval	OPW-series-nozzles.pdf	
Hose	Continental ContiTech E85 hose	Manufacturer Approval	Continental ContiTech -E8 5Hose.pdf	

### Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

### Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

#### Correspondence Contact

<b>Submitter Name</b>	Ravindra Penmatsa	<input checked="" type="checkbox"/> By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
<b>Job Title</b>	President	
<b>Company</b>	America Petropump Services LLC d/b/a Ampsco Services	
<b>Phone Number</b>	(312) 286-6722	
<b>Email</b>	ravi@ampsco.net	
<b>Contractor License #</b>	IL002420	