



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 2047238

Facility Name Love's Travel Stop #834
Address 8316 North Route 1
Grant Park, IL 60940
County Kankakee
Contact Name Brett Rothgeb
Phone Number (815) 465-1005

Tank - 2

Tank Material Fiberglass Double Wall
Tank Capacity 12,000
Tank Install Date 6/9/2021
Current Product on File Gasoline - Regular
Newly Reported Product E98

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval	XERXES E98 COMPATIBLE UST UGPetroleumStorageTankWa rr.5.1.2019 B99 & E85.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Franklin Fueling Systems UPP	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Blending Sump	Bravo Sump	Manufacturer Approval	BRAVO Altern._Fuel_and_Fuel_Comp._Statement_PE_Stamped_2024.pdf	
Single Wall STP/Tanktop Sump	Bravo Sump	Manufacturer Approval	BRAVO Altern._Fuel_and_Fuel_Comp._Statement_PE_Stamped_2024.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Franklin Fueling FMP-E1S	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	
ATG Probe	Franklin Fueling FMP-LL3-125-1	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Franklin Fueling - INC-TS-ELLD	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Franklin Fueling FMP-ULS	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Franklin Fueling - EBW L 708556901	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Fueling - EBW L 708692922	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	
Overfill Alarm	Franklin Fueling INC TS-RA1	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin Fueling FEP L 402568924-2HP	Manufacturer Approval	FRANKLIN FUELING E98 COMP ATIBILITY - ALL PARTS.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Seals / Gaskets	Viton	Manufacturer Approval	Viton.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dope	Gasolia	Manufacturer Approval	E-SealPipeDope E85.pdf	

Correspondence Contact

Submitter Name Anthony Mannino
Job Title Project Manager
Company Illinois Oil Marketing Equipment
Phone Number (309) 347-1819
Email amannino@iome.com
Contractor License # IL1293

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.