



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 2046874

Facility Name Lenny's Gas N Wash
Bourbonnais, LLC
Address 5916 N Convent
Bourbonnais, IL 60914
County Kankakee
Contact Name Donna Smith
Phone Number (815) 523-1260

Tank - 3

Tank Material Fiberglass Double Wall
Tank Capacity 10,000
Tank Product E85
Tank Install Date 8/8/2019

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Lab Certification	Xerxes.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Shear Valves	opw	Lab Certification	OPW Drop tube Adapters Im pact Valves.pdf	
Flex Connector	Franklin	Lab Certification	Fire flex flexes.pdf	
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Lab Certification	Ameron Piping.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single wall UDC	Bravo	Lab Certification	Bravo Sumps.pdf	
Single Wall STP/Tanktop Sump	Xerxes	Lab Certification	Xerxes Containment Sump U pgrades (1).pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors	794380-303	Manufacturer Approval	E85 sensors.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root	Lab Certification	Veeder Root Sensors.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794390-323	Lab Certification	Veeder Root Sensors.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Fe Defenders	Lab Certification	Defender spill bucket.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	opw 71SOM	Lab Certification	OPW Drop tube Adapters Im pact Valves.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco Dispensers	Gilbarco	Lab Certification	Gilbarco.pdf	
Submersible Pump	FE Petro	Lab Certification	Fe Petro Subs.pdf	
Nozzles and hoses	Catlow	Lab Certification	Catlow.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Caps and Rings	veeder root	Lab Certification	Cap and Ring E85 Compatib ility.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gaseola e seal	Lab Certification	Gasoila Pipe dope.pdf	

Correspondence Contact

Submitter Name

Job Title

Company

Phone Number

Email

Contractor License #

Steve Kryl

Project Manager

Anderson Pump Service, Inc.

(708) 243-9081

Steve@andersonpump.com

IL002275

☒

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.