

**Blended Fuel Compatibility Form****Facility - New**

Facility Name Lenny's Gas N Wash 143rd Street, LLC
Address 15907 W. 143rd Street
Lockport, IL 60441
County Will
Contact Name Lenny McEnery
Phone Number (708) 444-0117

Tank - 3

Tank Material Tank - Fiberglass Double Wall
XERXES
Tank Capacity 10,000
Tank Product E85
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES Fiberglass	Manufacturer Approval	e85 xerxes.pdf	From Permit Application

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Fiberglass Dualoy 3000/LCX	Lab Certification	e85 frp pipe.pdf	From Permit Application
Ball Valves	Franklin Fuel	Manufacturer Approval	e85 franklin all.pdf	From Permit Application
Other Riser	Steel	Lab Certification	E85 equipment approvals U S Department of Energy.pdf	From Permit Application
Flex Connector Steel	Franklin Fuel	Manufacturer Approval	e85 franklin all.pdf	From Permit Application
Fiberglass Single Wall Piping single wall vent	Ameron Fiberglass 4000 L	Manufacturer Approval	e85 frp pipe.pdf	From Permit Application
Shear Valves	OPW10	Manufacturer Approval	e85 opw.pdf	From Permit Application

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump and dispenser sumps	Bravo B421 and B1250	Manufacturer Approval	e85 bravo.pdf	From Permit Application

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors With Monitor	Veeder Root 794380-345	Manufacturer Approval	e85 veeder sensor.pdf	From Permit Application
ATG Probe	Veeder Root 846400-407	Manufacturer Approval	e85 probe.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 859080-001	Lab Certification	e85 plld.pdf	From Permit Application
UDC Sensor	Veeder Root 794380-323	Manufacturer Approval	E85 sensors.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Franklin 705555111-gkt	Manufacturer Approval	e85 franklin spill.pdf	From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-410M	Manufacturer Approval	e85 opw.pdf	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dispenser	gilbarco 700S	Manufacturer Approval	e85 gilbarco.pdf	
Submersible Turbine Pump	Fe Petro	Manufacturer Approval	e85 franklin stp.pdf	
Nozzle	opw	Manufacturer Approval	e85 opw.pdf	
Hose	opw	Manufacturer Approval	e85 opw.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
None that are not part of an approved device	None that are not part of an approved device	Not Applicable		None that are not part of an approved device

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
dope	Gasola E Seal	Manufacturer Approval	e85 dope.pdf	

Correspondence Contact

Submitter Name Stephen Kryl
Job Title Project Manager
Company Anderson Pump Service
Phone Number (708) 243-9081
Email Steve@andersonpump.com
Contractor License # IL002275

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.