

**Blended Fuel Compatibility Form**

Facility - 2007087

Facility Name Speedway #5373
Address 447 N. Bolingbrook Dr.
Bolingbrook, IL 60440
County Will
Contact Name Richard Acheampong
Phone Number (630) 759-3006

Tank - 11

Tank Material Fiberglass Double Wall
Tank Capacity 4,000
Tank Product E-85
Tank Install Date 8/7/2014

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	CSI-compatibility.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Shear Valves	OPW Double Poppet Shear Valve	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-product-s-2018.pdf	From Permit Application
Flexible Double Wall	Franklin Fueling Systems UPP	Manufacturer Approval	FFS-0513+Fuel+Compatibility+Reference+Guide+01-17.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Petroleum Containment Inc	Manufacturer Approval	pci-biodiesel.pdf	
Single Wall UDC	Petroleum Containment Inc	Manufacturer Approval	pci-biodiesel.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root/794380-345	Manufacturer Approval	577013-750-13_Solid-State Alternative Ethanol Fluid Interstitial Sensor_for _Double-Wall_Fiberglass_Tanks.pdf	
ATG Probe	Veeder Root/846397-407	Manufacturer Approval	577014-449-08_Stainless_Steel_Mag_Plus_In-Tank_Probe_Alternative_Fluids.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root/859080-001	Manufacturer Approval	576047-319_Electronic_Pressurized_Line_Leak_Detection_Datasheet.pdf	
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root/794380-323	Manufacturer Approval	577013-750-10_Position_Sensitive_Sensor.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	opw-1c-2100	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	opw-71som-412c	Manufacturer Approval	71SO_Overfill_Prevention_Valve.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco Flex Dispenser	Gilbarco encore Series	Manufacturer Approval	Encore Flex Fuel Dispenser _ Gilbarco Veeder-Root.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact		☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Submitter Name	Ravindra Penmatsa	
Job Title	Business Director	
Company	America Petropump Services LLC d/b/a Ampsco Services	
Phone Number	(312) 286-6722	
Email	ravi@ampsco.net	
Contractor License #	IL002420	