

**Blended Fuel Compatibility Form**

Facility - 2014721

Facility Name Elmwood Park Phillips 66 Address 7750 West Grand Avenue Elmwood Park, IL 60635 County Cook Contact Name Haytham Albusalah Phone Number (708) 945-1076	Tank - 3 Tank Material Steel Single Wall Tank Capacity 4,000 Tank Product E-85 Tank Install Date 3/1/1974
---	--

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Steel Single Wall	Bridgeport lining	Manufacturer Approval	bridgeport tank lining.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech S150SC	Manufacturer Approval	franklin apt pipe.pdf	From Permit Application
Flex Connector Steel	Hose Master, Fire Shield	Manufacturer Approval	hose master flex connectors.pdf	From Permit Application
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	NOV LCX pipe and fittings.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Dispenser Sump	OPW, Pisces series	Manufacturer Approval	opw all products.pdf	
Single Wall STP/Tanktop Sump	OPW, Pisces series dispenser & pump sump	Manufacturer Approval	opw all products.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Veeder Root	TLS 350	Manufacturer Approval	veeder root probes.pdf	
ATG Probe	Veeder Root, 846391-407	Manufacturer Approval	veeder root probes.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Franklin 403169901	Manufacturer Approval	franklin mlld.pdf	Existing
Non-Discriminating Sump Sensor with positive shutdown	Veeder Root 794380-323	Manufacturer Approval	veeder root sensors all.pdf	Existing

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1-2100EVR	Manufacturer Approval	Opw spill containers.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Fueling, Defender	Manufacturer Approval	FFS-0392 Defender Series OPV Datasheet.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Franklin 4020159	Manufacturer Approval	franklin stp.pdf	
Dispenser	Wayne EB23/5220D3	Manufacturer Approval	wayne dispensers all.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Ed Angell
Job Title Project Manager
Company B&K Equipment Company
Phone Number (708) 474-3344
Email ed@bkequip.com
Contractor License # IL1207

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.