

**Blended Fuel Compatibility Form**

Facility - 2032055

Facility Name Roosevelt Foods
Address 2401 W. Roosevelt Rd.
Chicago, IL 60608
County Cook
Contact Name Fadi Khalil
Phone Number (708) 259-9316

Tank - 7

Tank Material Tank - Composite Double
Wall Lannon
Tank Capacity 5,000
Tank Product E85
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Lannon Tank	Manufacturer Approval	Tank-Compatibility-RFA.pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall Piping Vent	NOV Fiberglass	Manufacturer Approval	Tank-Compatibility-RFA.pdf	New from Permit Application.
Other Pump	Submersible	Manufacturer Approval	FFS-0513+Fuel+Compatibility+Reference+Guide+01-17.pdf	New from Permit Application.
Flexible Double Wall	Franklin Fueling Systems UPP	Manufacturer Approval	FFS-0513+Fuel+Compatibility+Reference+Guide+01-17.pdf	New from Permit Application.
Shear Valves	OPW -10Plus Series	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-product-s-2018.pdf	New from Permit Application.

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Petroleum Containment INC	Manufacturer Approval	pci-biodiesel.pdf	New from Permit Application.
Single Wall UDC Sump	Petroleum Containment Inc	Manufacturer Approval	pci-biodiesel.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root-794380-430	Manufacturer Approval	577013-750-16_Interstitial_High_Alcohol_Sensor_for_Steel_Tanks.pdf	New from Permit Application.
ATG Probe	Veeder Root-846397-409	Manufacturer Approval	577014-449-08_Stainless_Steel_Mag_Plus_In-Tank_Probe_Alternative_Fluids.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root-859080-001	Manufacturer Approval	576047-319_Electronic_Pressurized_Line_Leak_Detection_Datasheet.pdf	New from Permit Application.
Sump Sensor with positive shutdown	Veeder Root-794380-323	Manufacturer Approval	577013-750-10_Position_Sensitive_Sensor.pdf	New from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW-3100C Series Edge	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW-71SOM-412C	Manufacturer Approval	71SO_Overfill_Prevention_Valve.pdf	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin Fueling-STP-AG series	Manufacturer Approval	FFS-0513+Fuel+Compatibility+Reference+Guide+01-17.pdf	
Dispenser	Gilbarco-Encore Flex Dispensers	Manufacturer Approval	Encore Flex Fuel Dispenser _ Gilbarco Veeder-Root. pdf	
Nozzle	OPW-11BP-0992-E85	Manufacturer Approval	OPW-series-nozzles.pdf	
Hose	Continental Conti Tech	Manufacturer Approval	Continental ContiTech -E85Hose.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gaskets and Seals from Lannon	Lannon Tank	Manufacturer Approval	tank-manufacturer-compatibility.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gasola	Gasola E-seal	Manufacturer Approval	Gasola Compatibility.pdf	

Correspondence Contact

Submitter Name Ravindra Penmatsa
Job Title President
Company America Petropump Services LLC d/b/a Ampsco Services
Phone Number (312) 286-6722
Email ravi@ampsco.net
Contractor License # IL002420

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.