

**Blended Fuel Compatibility Form**

Facility - 2017198

Facility Name Aden Gas, Inc.
Address 8649 S. Ashland Ave.
Chicago, IL 60620
County Cook
Contact Name Mohamed Hujaji
Phone Number (708) 983-9620

Tank - 6

Tank Material STIP3 Single Wall
Tank Capacity 8,000
Tank Product E85
Tank Install Date 2/23/1990

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STIP3 Single Wall	UNKNOWN	Manufacturer Approval	sti_fuels_compatibility_statement.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Shear Valve	OPW 10	Manufacturer Approval	opw_eth_compat PISCES.pdf	
Galvanized Steel Single Wall Piping	OPW / BMA-1515 (flex pipe barb fitting)	Manufacturer Approval	opw_all_products.pdf	Replacing from Permit Application.
Flexible Double Wall	OPW Pisces	Manufacturer Approval	opw_eth_compat PISCES.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	OPW poly	Manufacturer Approval	opw_eth_compat PISCES.pdf	
Single Wall UDC Sump	OPW poly	Manufacturer Approval	opw_eth_compat PISCES.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	VEEDER-ROOT 846397-407	Manufacturer Approval	veeder root probes.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Franklin 403169901	Manufacturer Approval	Franklin MLD AG.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Emco A1004	Manufacturer Approval	Emco A1004 & 1005 contain ers.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Emco Wheaton A1100	Manufacturer Approval	EMCO A1100 Overfill Prevention Valve.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Fe Petro AG	Manufacturer Approval	franklin stp.pdf	
Dispenser	Wayne Ovation 2 EB23	Manufacturer Approval	Wayne Ovation EB23.pdf	
Nozzle	OPW 11BP	Manufacturer Approval	opw-11bp-series-ethanol-nozzles_2018.pdf	
Hose	Goodyear	Manufacturer Approval	Continental_Goodyear_flex steel hoses.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fill cap	OPW	Manufacturer Approval	OPW compatibility.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Thread sealant	Gasolite E-Seal	Manufacturer Approval	gasolite dope.pdf	

Correspondence Contact

Submitter Name Ben Olthoff
Job Title Project Manager
Company B & K Equipment Company
Phone Number (708) 474-3344
Email ben.olthoff@bkequip.com
Contractor License # IL1207

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.