

**Blended Fuel Compatibility Form**

Facility - 4034108

Facility Name Circle K #1438
Address 3604 North Mattis
Champaign, IL 61822
County Champaign
Contact Name Linda Capozzi
Phone Number (217) 355-1873

Tank - 4

Tank Material Fiberglass Double Wall
Tank Capacity 4,000
Tank Product E-85
Tank Install Date 11/15/1997

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Dualoy 3000/LCX	Manufacturer Approval		
Shear Valves	OPW / 10 Series	Manufacturer Approval		
Flex Connectors	OPW / FC20 Stainless Flex Connector	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Containment Solutions / STP Sump	Manufacturer Approval		
Under Dispenser Containment	Bravo / B7000	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors	Veeder Root / 794380-303	Manufacturer Approval		
ATG Probe	Veeder Root / Mag Plus Probe	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root / PLLD	Manufacturer Approval		
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root / Piping sump sensor	Manufacturer Approval		Bell sensor not compatible. Need to install the correct sensor.
Under dispenser containment leak detection	Veeder Root - Position Sensitive Sensor 794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW / Edge Double Walled Spill Container	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Red Jacket / 1.5hp 410141-020	Manufacturer Approval		
Dispenser	Gilbarco / Encore 700	Manufacturer Approval		
Dispenser Nozzle	OPW / 11BP	Manufacturer Approval		
Dispenser Hoses	Continental / Ethan-all E85 559N	Manufacturer Approval		
Dispenser Breakaway	OPW / 66V Breakaway	Manufacturer Approval		
Swivel	OPW / 241TPS-0492	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact		☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Submitter Name	Brian Niederschmidt	
Job Title	Estimator	
Company	Neumayer	
Phone Number	(636) 515-4517	
Email	brian_niederschmidt@neumayerequipment.com	
Contractor License #	IL1502	