



Blended Fuel Compatibility Form

Facility - 2042050	Tank - 3
Facility Name 9856 South Cicero, LLC	Tank Material Fiberglass Double Wall
Address 9856 S. Cicero Avenue Oak Lawn, IL 60453	Tank Capacity 5,000
County Cook	Tank Product E-85
Contact Name Besmir Latifaj	Tank Install Date 11/15/2017
Phone Number (708) 581-4139	

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Omega Flex Double Trac	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	bravo	Manufacturer Approval		
Bravo dispenser sump	Bravo	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Veeder Root, Model #794380-345	Veeder Root	Manufacturer Approval		
ATG Probe	Veeder Root, Model #846391-607	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	FE Petro	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root, Model #794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	Franklin EBW Below Grade	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW, part #71SOM-412C	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
FE Petro Submersible	STPAG75-VL2	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Warren Cherner

Job Title President

Company Metro Tank and Pump Company

Phone Number (847) 465-4000

Email warren@metrotank.com

Contractor License # IL102

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.