



Blended Fuel Compatibility Form

Facility - 2043408

Facility Name 82nd Real Estate, Inc.
Address 8145 S. Pulaski Road
 Chicago, IL 60652
County Cook
Contact Name Stephen Chacko
Phone Number (773) 671-9864

Tank - 4

Tank Material Composite Double Wall
Tank Capacity 3,000
Tank Product E-85
Tank Install Date 9/14/2006

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	ACT 100	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	ENVIRON GEOFLEX	Lab Certification		SEE TABLES 2 & 3

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Dispenser Sump	OPW, Pisces series	Manufacturer Approval		
Single Wall STP/Tanktop Sump	ENVIRON GEOFLEX	Lab Certification		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root, 846391-407	Manufacturer Approval		
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 794380-430	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Franklin 403169901	Manufacturer Approval		
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	101-BG	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Fueling, Defender	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dispenser	Wayne, Ovation B	Manufacturer Approval		
Pump	Franklin Fueling, STPAG	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Edward Angell
Job Title Project Manager
Company B&K Equipment Company
Phone Number (708) 474-3344
Email ed@bkequip.com
Contractor License # IL1207

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.