



Blended Fuel Compatibility Form

Facility - 5031239

Facility Name	Thorntons, Inc. #9280
Address	#1 Burwell Drive Lincoln, IL 62656
County	Logan
Contact Name	Matt Coffing
Phone Number	(502) 523-9126

Tank - 2

Tank Material	Fiberglass Double Wall
Tank Capacity	12,000
Tank Product	B-99
Tank Install Date	11/23/1992

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Owens Corning	Manufacturer Approval		Owens Corning tank

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Steel Single Wall Piping	unknown	Manufacturer Approval		Above ground 3" piping

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP sump	APT	Manufacturer Approval		Model# 602402901

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root	Manufacturer Approval		Model# 794380-343
ATG Probe	Veeder Root	Manufacturer Approval		Model# 846397-309
Probe floats	Veeder Root	Manufacturer Approval		Model# 846400-002

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
None	None	Not Applicable		This is above ground single wall black steel piping running to a loading arm

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW Edge	Manufacturer Approval		Model# 1C-3112D

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Drop tube valve	OPW	Manufacturer Approval		Model# 71SO-410CB

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	FE Petro	Manufacturer Approval		Model# STP-AG5-145-54

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name James Franklin
Job Title Construction Manager
Company Seneca Companies
Phone Number (515) 601-6635
Email jfranklin@senecaco.com
Contractor License # IL598

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.