



Blended Fuel Compatibility Form

Facility - 2047287

Facility Name Lenny's Gas N Wash 127th and Kostner, LLC
Address 4361 W. 127th Street Alsip, IL 60803
County Cook
Contact Name Leonard McEnery
Phone Number (708) 444-0117

Tank - 5

Tank Material Fiberglass Double Wall
Tank Capacity 10,000
Tank Product E85
Tank Install Date 11/15/2021

Tank Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|------------------------|--------------------|-----------------------|----------------|---------|
| Fiberglass Double Wall | XERXES | Manufacturer Approval | e85 xerxes.pdf | |

Piping Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|------------------------|------------------------|----------------------|------------------|---------|
| Fiberglass Double Wall | Ameron Dualoy 3000/LCX | Lab Certification | e85 frp pipe.pdf | |

Containment Sump Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|------------------------------|--------------------|-----------------------|---------------|---------|
| Single Wall STP/Tanktop Sump | Bravo | Manufacturer Approval | e85 bravo.pdf | |
| Single Wall UDC Sump | Bravo B1000 | Manufacturer Approval | e85 bravo.pdf | |

Release Detection Tank Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|---|------------------------|----------------------|------------------------|-------------------------|
| Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors | Veeder Root 794380-345 | Lab Certification | Veeder Root compat.pdf | From Permit Application |

Release Detection Piping Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--|------------------------|-----------------------|-----------------|---------|
| Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump | Veeder Root 794380-323 | Manufacturer Approval | E85 sensors.pdf | |

Spill Prevention Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------------|-----------------------------------|-----------------------|------------------------|---------|
| Double Wall Spill Bucket | FE Petro Defender 705555112CI-GKT | Manufacturer Approval | e85 franklin spill.pdf | |

Overfill Prevention Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------------|--------------------|-----------------------|-------------------|---------|
| Overfill Drop Tube Valve | OPW 71SOM-412C | Manufacturer Approval | e85 drop tube.pdf | |

Pump Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------|--------------------|----------------------|---------------------|---------|
| Gilbarco | E700 S | Lab Certification | gilbarco compat.pdf | |

Gaskets & Seals Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------|--------------------|----------------------|---------------|---|
| gaskets and seals | None | Not Applicable | | None that are not part of an approved assembly. |

Joint Dopes & Adhesives Equipment

| Compatibility Item | Model/Manufacturer | Compatibility Method | Documentation | Comment |
|--------------------|--------------------|-----------------------|-------------------|---------|
| Gasola E Seal | Gasola E Seal | Manufacturer Approval | Gasola compat.pdf | |

Correspondence Contact

Submitter Name Stephen Kryl
Job Title Project Manager
Company Anderson Pump Service, Inc.
Phone Number (708) 243-9081
Email steve@andersonpump.com
Contractor License # IL002275

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.