



Blended Fuel Compatibility Form

Facility - 2040315		Tank - 15	
Facility Name	Speedway #3996	Tank Material	Fiberglass Double Wall
Address	31776 N Highway 12 Volo, IL 60073	Tank Capacity	6,000
County	Lake	Tank Product	E-85
Contact Name	Store Manager	Tank Install Date	1/17/2018
Phone Number	(815) 385-3438		

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	CSI-compatibility.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	OPW Flexworks	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall/UDC	Petroleum Containment Inc	Manufacturer Approval	pci-biodiesel.pdf	
Single Wall STP/Tanktop Sump	Petroleum Containment Inc	Manufacturer Approval	pci-biodiesel.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root/846391-407	Manufacturer Approval	577014-449-08_Stainless_Steel_Mag_Plus_In-Tank_Probe_Alternative_Fluids.pdf	
Non-Discriminating Interstitial Monitoring Sensors With Monitor	Veeder Root/794380-345	Manufacturer Approval	577013-750-13_Solid-State_Alternative_Ethanol_Fluid_Interstitial_Sensor_for_Double-Wall_Fiberglass_Tanks.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root/859080-001	Manufacturer Approval	576047-319_Electronic_Pressurized_Line_Leak_Detection_Datasheet.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root/794380-323	Manufacturer Approval	577013-750-10_Position_Sensitive_Sensor.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW-1C-2100	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW-71SOM	Manufacturer Approval	71SO_Overfill_Prevention_Valve.pdf	
Overfill Alarm	Veeder Root/Overfill Alarm Box (Part No. 790091-001)	Manufacturer Approval	576047-241_Overfill_Alarm.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Wayne Dispensers	Wayne Helix	Manufacturer Approval	f2e78a_835d0167ea09428d85d7ffee56f8d1a6.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Ravindra Penmatsa
Job Title Business Director
Company America Petropump Services
 LLC d/b/a Ampsco Services
Phone Number (312) 286-6722
Email ravi@ampsco.net
Contractor License # IL002420

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.