

**Blended Fuel Compatibility Form****Facility - New**

Facility Name Casey's General Stores
#4312
Address 741 E Lincoln Highway
Hinckley, IL 60520
County De Kalb
Contact Name Lee Lytle
Phone Number (515) 446-6231

Tank - 3

Tank Material Tank - Fiberglass Double Wall
Containment Solutions
Tank Capacity 8,000
Tank Product E15
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	CSI Compatibility.pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech S175SC	Manufacturer Approval	FFS-0524 XP Flexible Pipe work Datasheet.pdf	New from Permit Application.
Shear Valve	Franklin	Manufacturer Approval	Franklin Fueling Compatibility Products.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Containment Solutions tank sumps	Manufacturer Approval	CSI Compatibility.pdf	New from Permit Application.
UDC's	Franklin dispenser sump, part #LMD-2715	Manufacturer Approval	Franklin Fueling Compatibility Products.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root, part #794380-345	Manufacturer Approval	Veeder Root Compatibility .pdf	New from Permit Application.
ATG Probe	Veeder Root, Model #846391-607	Manufacturer Approval	Veeder Root Compatibility .pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root DPLLD, part #859080-001	Manufacturer Approval	Veeder Root Compatibility .pdf	New from Permit Application.
Sump Sensor with positive shutdown	Veeder Root, part #794380-208	Manufacturer Approval	Veeder Root 208 Sump Sensor.pdf	New from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Franklin, EBW defender overspill, part #705556111BLK	Manufacturer Approval	Franklin Fueling Compatibility Products.pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin, part #708691922	Manufacturer Approval	Franklin Defender Series OPV Datasheet.pdf	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	STPAG75-VL2	Manufacturer Approval	FE Petro E15 Submersible.pdf	
Dispenser	Gilbarco, Encore 700	Manufacturer Approval	Gilbarco Encore.pdf	
Nozzle	OPW, 11BP-0992-E85	Manufacturer Approval	opw-11bp-series-ethanol-n ozzles_2018.pdf	
Hose	Continental	Manufacturer Approval	OPW-Fuel+Compatibility+Ma trix+(Below+Ground) (12).pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gasket	Containment Solutions	Manufacturer Approval	CSI Compatibility.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasola	Manufacturer Approval	Gasola Compatibility.pdf	

Correspondence Contact

Submitter Name Warren Cherner
Job Title President
Company Metro Tank and Pump Company
Phone Number (847) 465-4000
Email warren@metrotank.com
Contractor License # IL102

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.