

Michael OConnell

From: PEMCO Service Co Inc <pemcogilman@sbcglobal.net>
Sent: Tuesday, July 5, 2022 5:23 PM
To: Kyle Deornellas; Mike Hall Jr.; Charlie Moore; Michael O'Connell
Subject: FW: E-85 Compatible

From: JoshD@dpm-llc.com <JoshD@dpm-llc.com>
Sent: Tuesday, July 5, 2022 4:41 PM
To: 'PEMCO Service Co Inc' <pemcogilman@sbcglobal.net>
Subject: E-85 Compatible

Hi Butch,

Our Spill Liner repairs are E-85 Compatible. There should be no issue using them in this application.

Please let me know if you need anything else.

Thanks,

Josh Dow

Diversified Products Manufacturing Inc. &
Diversified Distribution Centers
5523 Baggett Marysville Rd
Oroville, CA 95965
(530) 534-3966
joshd@dpm-llc.com

