



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 4031618

Facility Name Casey's General Store
#2927

Address 207 S. Center Street
Forrest, IL 61741

County Livingston

Contact Name Jill Reams-Widder

Phone Number (515) 965-6238

Tank - 3

Tank Material STIP3 Single Wall

Tank Capacity 6,000

Tank Product E-85

Tank Install Date 3/9/1993

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STIP3 Single Wall	Mid South Steel	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech S175SC	Manufacturer Approval		
shear valve	EBW 662501902	Manufacturer Approval		
flex connector	Franklin Fueling	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Franklin Fueling/ APT	Manufacturer Approval		
Single wall UDC	Franklin Fueling LMM-3617	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
NA	NA	Not Applicable		NA
ATG Probe	Veeder Root	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	veeder root	Manufacturer Approval		
Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	veeder Root	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	EBW	Manufacturer Approval		

Overfill Prevention Equipment

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	EBW	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible pump	FE Petro	Manufacturer Approval		
Hanging Hardware	Husky	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe dope	Gasolia	Manufacturer Approval		

Correspondence Contact

Submitter Name James Franklin
Job Title Construction Manager
Company Seneca Companies
Phone Number (515) 601-6635
Email jfranklin@senecaco.com
Contractor License # IL598

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.